

**Draft amendment to the
2018 IECC
Section R402.1 and R503.2**

R402.1

Add exception 3.

3. Attached or detached garages that meet all of the following:
 - 3.1 Walls exposed to the exterior with entire cavities filled with insulation minimum **R-13** for 2x4 construction or R-19 for 2x6 construction.
 - 3.2 Attic above garages have at least an R-19 blanket or loose fill insulation
 - 3.3 Overhead doors have a minimum **R-4.75** insulation.
 - 3.4 Heating source is separate from and not in addition any other heating source.
 - 3.5 Heating source total maximum output rating of $\leq 50,000$ Btu/h. ^a

a. Equipment sizing requirements of section R403.7 are not required.

R503.2

Add exception 2.

2. Attached or detached garages are exempt from the requirements of table R402.1.2 when conditioning the space for occasional use or freeze protection.