

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

ADAM KAMPENHOUT **2**

<u>Permit No</u>	<u>Scheduled Date Completed Date</u>	<u>Remarks</u>	<u>Result</u>	<u>Notes</u>
VER1503-00001	04/23/2015		PASS	(4/23/2015 2:42 PM AKA) BNW 7.00-3.00
	04/23/2015			Ivan Miller - Final PASS 603 Ellis Lane PLMR
				Mtg w Mel Rogers - Ellis Rd re inspections needed and building code questions.
				John Walker - Framing corrections to deck - PASS Add 180 days to permit. 111 Grandma's Way, StM
				Karen Gibson - Real Prop insp - first pay fee \$211.65 or chk w courthouse if inspection was already paid for and completed. (Should have been verified at time of set by Norm Suenkel)
				Mtg we County clerk staff re fee schedule and reporting. Research if on CDA reservation, native members have to obtain permits? (Nez Perce - NP County dont if they are NA)
				CR for Marty Snow load May city in Lemhi County - not listed on tables because too great variations according to proprty locations. Best to call Theresa or Gary @ 208 756-2825 x 263.
	04/22/2015		PASS	Left msg w Marty @ 800 434-4893 (4/23/2015 2:54 PM AKA)
	04/22/2015			BI 6:30-19:30 = 13 hrs IRIC Pour II 6:30-12:30 ITD Final/LOC 12:30-13:30 Orofino - State Hosp North precon and site visit and travel time 13:30-19:30 C-BNW calls and Bus 17:30-18:30

ANDY ROSE **1**

<u>Permit No</u>	<u>Scheduled Date Completed Date</u>	<u>Remarks</u>	<u>Result</u>	<u>Notes</u>
VER1505-00001	05/28/2015		ADMIN TIME	(5/28/2015 2:11 PM ARO)
	05/28/2015			8hrs new employer training

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

BRAD MYERS

15

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1504-00001	04/28/2015 04/28/2015		ADMIN TIME	(4/28/2015 12:17 PM BMJ) improccessing in meridian office
	05/06/2015 05/06/2015		ADMIN TIME	(5/7/2015 7:58 AM BMJ) I had no inspection for the day, so I studied the code book to try and get ready for go take my test. I also went out and did so compliance check with some contractor. This was kind of a transition day to get Curt and Grant inspection transfer over to me in the Mini-Cassia area.
	06/18/2015 06/18/2015		ADMIN TIME	(6/18/2015 2:05 PM BMJ) Spent time in office studying for my inspectors test.
	06/11/2015 06/11/2015		ADMIN TIME	(6/11/2015 1:07 PM BMJ) When I showed up to work today I found that I had no inspection for the day. I looked to see if I could help Curt or Grant with there inspection and they only have a couple as well. I am able to take advantage of this time to study to take my test. I have been studying. I also went out to do a little bit of compliance work but everyone I check was good to go. I was only able to find 3 location where there was work going on. I am back to studying now for the remainder of work unless my phone ring to go check on a job.
	05/11/2015 05/11/2015		ADMIN TIME	(5/13/2015 7:37 AM BMJ) We had a compliance meeting in Shoshone with Terry Blessing. This meeting was from 8am to about 930am.
	06/10/2015 06/10/2015		ADMIN TIME	(6/10/2015 2:04 PM BMJ) After my inspection were completed I have been looking at the books studing. going thur champter 5 and 6 today.
	06/02/2015 06/02/2015		ADMIN TIME	(6/2/2015 2:58 PM BMJ) Took my harassment class and have been studing to take the inspector test.
	04/29/2015 04/29/2015		ADMIN TIME	(4/30/2015 10:25 PM BMJ) Code Update Training and travel time
	06/09/2015 06/09/2015		ADMIN TIME	(6/10/2015 2:02 PM BMJ) I had 1 inspection today. After I went tto check on this inspection to see if they were completed, I came back to the office and have been studing to attempt to take my test. I have been looking at the books for a couple of hours a day but today I am getting to look at it for about 6 hours. I wnet back out to check on the inspection that I was scheduled for and they were not complete. I moved the inspection to 6-10-15

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
 For the Period 4/1/2015 thru 6/30/2015

VER1504-00001	04/30/2015	ADMIN TIME	(4/30/2015 10:27 PM BMY)
	04/30/2015		Training with Larry in the Bellevue office for the entire day
	05/05/2015	ADMIN TIME	(5/6/2015 7:41 AM BMY)
	05/05/2015		Met Curt Bingham in Twin Falls at the DOL office. He took me around and did inspection in the Cassia County area. Got me familiar with the area and showed me some of the bigger job in the area. Showed me the hard to find areas.
	06/18/2015	COMPLIANCE	(6/18/2015 2:06 PM BMY)
	06/18/2015		Went to a couple of job sites to check out contractor. Everyone I check was able to provide me with cards.
	04/27/2015	ADMIN TIME	(4/30/2015 10:23 PM BMY)
04/27/2015		improccessing in meridian office	
06/17/2015	ADMIN TIME	(6/18/2015 2:09 PM BMY)	
06/17/2015		After I completed my inspection for the day I was able to study for my test. I only had a couple of inspection in my area, so I was able to go help grant out in his area since he was covering for curt.	
05/04/2015	ADMIN TIME	(5/4/2015 1:26 PM BMY)	
05/04/2015		Reported to the Burley Office. I rode around with Grant Loveless visiting various contractor and learding the area to be able to go out on my own.	

BRUCE HOLLAND **13**

Permit No	Scheduled Date Completed Date	Remarks	<u>Result</u>	<u>Notes</u>
VER1501-00004	04/03/2015		COMPLIANCE	(4/3/2015 5:17 PM BHO)
	04/03/2015			asked to stop at job in mountain home spent time on code/compliance with J&J heating, cooling and electric
	06/05/2015		PASS	also talked with plumber on job John Gross (6/5/2015 4:29 PM BHO)
	06/05/2015			met Tell Riley Elmore county building official on job site, have only talked to on phone prior
	06/16/2015		PASS	(6/16/2015 2:42 PM BHO)
	06/16/2015			checked license of contractors on site while doing inspection fo0r another trade JAROD WHITING HVC-J-5729 JESSE DEEDS HVC-A-016571

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00004	06/26/2015 06/26/2015	PASS	(6/26/2015 3:43 PM BHO) while performing several inspections in Avimor I check license with 2 separate trade HVAC and Plumbing SHANE SANGSTER PLB-A-017086 TREVOR LEWIS PLB-A-1786
	06/26/2015 06/26/2015	PASS	ROMON QUITERO JOSE LAGUNAS RIGOBERTO LAGUNS, all checked in our office by inspector support via email (6/26/2015 3:49 PM BHO) WEB1504-02374 418 N 4thW stopped by this house per conversation with Brandee about a voicemail left in our office homeowner/tenant complained of a sewer smell from back yard, no issue with bad smell connected to permitted work done by contractor for new sewer in front yard
	05/22/2015 05/22/2015	PASS	(5/22/2015 4:05 PM BHO) stop by job by the request of local contractor doing work on permitted job contractor wanted technical advise
	05/14/2015 05/14/2015	PASS	(5/14/2015 4:44 PM BHO) stopped at a job that a home owner is starting, has permits in progress technical assistants
	03/31/2015 04/03/2015	PASS	(3/31/2015 3:55 PM BHO) I took my car to corwin ford for service oil change cab air filter rear alignment, toe was out
	04/27/2015 04/27/2015	PASS	(4/27/2015 3:15 PM BHO) went to Les Schwab to have winter tires removed and summer tires installed 1 hr.
	05/22/2015 05/22/2015	PASS	(5/22/2015 4:04 PM BHO) was asked to check possible work being done at the prison work taking place was demo only of abandoned steam lines and HVAC work had been completed and permitted
	05/11/2015 05/11/2015	PASS	(5/12/2015 3:18 PM BHO) stopped at les schwab, mountain home tire sensor reading flat, sensor was bad. I had them replace it. 1 hour, plus
	05/01/2015 05/01/2015	PASS	(5/1/2015 4:08 PM BHO) called to address for inspection WEB1504-02745 both plumber and HVAC on site, asked contractor for lic. PLUMBERS Mike Berg PLB-J-3767, has up to date lic. NICHOLAS DUREN PLB-A-012127
			HVAC JASON LANDERS HVAC-J-018981 FRANK HYLTON HVAC-J-017504

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00004	06/08/2015 06/08/2015	PASS	(6/8/2015 2:23 PM BHO) plumbing inspection requested by contractor, 6249 pershall, marsing HVAC contractor on site at time of inspection, ask employees of artic air for Licenses MANUAL LAGUNAS HVAC-J-3288 IRENE LAGUNAS HERNADEZ HVAC-A-015692
----------------------	--------------------------	------	---

CHRIS CRITSER

6

Permit No	Scheduled Date Completed Date	Remarks	<u>Result</u>	<u>Notes</u>
VER1501-00005	05/27/2015 05/27/2015		PASS	(5/28/2015 8:07 AM CCR) the camering of the sewer line took longer than i was expecting by the time they filled the pipe and it drained and the time trying to camera the line was about 2 hours in the mean time i went to look at a job for seth about a grease trap and then carded Cory A. Tverdy lic# 010960 exp. 9/30/17, pass
	06/03/2015 06/03/2015		ADMIN TIME	(6/4/2015 8:24 AM CCR) I TOOK THE UNLAWFUL HARASSMENT PREVENTION
	06/03/2015 06/03/2015		PASS	(6/4/2015 8:22 AM CCR) carded the electrician at the fair grounds CORY A. TVERDY, LIC#010960 EXP. 9/30/17
	06/10/2015 06/10/2015		ADMIN TIME	(6/10/2015 2:40 PM CCR) this is for a training class in pocatello for plumbing ceu's
	06/24/2015 06/24/2015		ADMIN TIME	(6/24/2015 4:48 PM CCR) went to arco to pick Adam up and take to Idaho fall also went over my evaluation,
	06/26/2015 06/26/2015		PASS	cody with bingham county gave me a call about 2 guys possible unlicensed doing hvac work in blackfoot at 172w 265n , he witness there finishing hvac system and working to find leak on gas line. when i showed up they just walked back in to continue to find leak in gas line i asked if they had licenses they told me they did not i asked for there driver licenses and here is there information. they are working AIRPRO SKYLER CORY MERRILL 1221W 90S BLACKFOOT IDAHO 83221 TIMOTHY PATRICK RIDING 560 HOLBROOK IDAHO FALLS IDAHO, 83401

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

CRAIG HAMMOND

17

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00008	06/02/2015		ADMIN TIME	(6/2/2015 12:04 PM CHA)
	06/02/2015			2 JUNE 2015 Repair Flat Tire Screw in the tire DRIGGS TIRE \$15.00
	06/12/2015		ADMIN TIME	(6/12/2015 2:16 PM CHA)
	06/12/2015			12 JUNE 2015 Complete the Unlawful Harassment Prevention course 1.5 hour
	05/21/2015		COMPLIANCE	(5/21/2015 11:06 AM CHA)
	05/21/2015			21 MAY 2015 SEWER LINE AT THE CHICKEN AND HOGS BUILDINGS Reviewed work with the 2 Ben's. They had a vent tee in the horz. drain line, I asked them to change it to a Y type fitting. Keep the cleanout within 2' of the buildings. Add extra cleanouts every 100' TDL, or 135 dergres change of direction.
	05/20/2015		COMPLIANCE	(5/20/2015 7:39 AM CHA)
	05/20/2015			19 MAY 2015 House located at 1875 salem pines Fremont County I went to look at the fireplace, it was covered with sheetrock and painted, the front was open but could not look up. I failed the job, Clay sent me a text that evening. I called him in the morning at 7:14 and ask why it was covered the sheet rockers had covered it. The contractor was Ryan Bradshaw at 208 390 4438. He said he would open up a spot to see. I called Ryan Bradshaw and said the fireplace opening for the chimney needs to stay open unil it has been inspected with a green tag. I said if it hasn't been inspected he is welcome to call me. They was all goo with hat. I aso called the homeowner and told him I needed a space to see clearances, he was ok also.
	05/07/2015		ADMIN TIME	(5/7/2015 11:11 AM CHA)
	05/07/2015			OIL CHANGE 7May 2015 Grease Monkey 2012 Ford Escape miles 104155
	04/21/2015		COMPLIANCE	(4/21/2015 10:37 AM CHA)
	04/21/2015			LICENSE CHECK David L. Shartzter J-HVAC ex. date 3-31-2016 Location Jackson Food store Ashton Id. Main st. company TRV inc

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

Case Number	Date	Category	Description
VER1501-00008	05/06/2015	COMPLIANCE	(5/6/2015 10:55 AM CHA) ENFORCEMENT 6 MAY 2015 Water line covered except for inside and the end of the trench. Blaine Nalder is the excavator HE is doing the sewer, I informed him not to cover it before inspection is complete. Location Island Park, Idaho 3324 Spur Cir. I called Chris Crister and ask him about Blain Naulder, he said he usally has something covered.
	05/06/2015		
	05/14/2015	ADMIN TIME	(5/14/2015 3:29 PM CHA) New Building Contractor Driggs Roaring Fork Construction LLC Grant Wilson ASK questions about building, and ect.
	05/14/2015		
	06/02/2015	COMPLIANCE	(6/2/2015 1:35 PM CHA) BRAKEMAN BERGER Reviewed the water line with Matkin (conningham) Deep soft shoulders the trench could cave in I said they could cover it in the blue tracer wire is in place.
	06/02/2015		
	04/17/2015	ADMIN TIME	(4/17/2015 11:20 AM CHA) 17 April 2015 Take studded snow tires to the store, we didn't have a place to store them. Les Schwab st, anthony Id.
	04/17/2015		
	04/17/2015	ADMIN TIME	(4/17/2015 11:16 AM CHA) 17 April 2015 FIX CHIPS IN THE WINDSHIELD 3 chips \$25.00 for the first, \$10.00 for each after. \$45.00 total A-1 Windshield 25 n 12th w rexburg Idaho 83440
	04/17/2015		
	05/18/2015	ADMIN TIME	(5/18/2015 5:06 PM CHA) ACCIDENT 18 May 2015 Backing out of my driveway, at about 8:43 a>m the neighbor backing up from accross the street hit my front passenger side door. I got his imformation, and had the police come over to ge a report. The police man was Tom Mattingly, It did not issue Ny citations but said it looked like ie was Angel Florses fault. I called Adam Bowcutt and he came up with another car he took mine to get some estaments. The car that hit me was going about 4- 5 mph, but sounded much harder. I sent the accident report to Adam Bowcutt, I have not yet recieved the police report.
	05/18/2015		

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00008	06/18/2015	COMPLIANCE	(6/18/2015 8:17 AM CHA)
	06/18/2015		I went to a job located 4025 Rasmussen Lane off hwy 20 past the H.L. outlet. The Owners name is Jeff CARMIGNANI . An addition to to an old house but not really connected. I looked at the sewer line it was 4" SCH. 40 to the septic tank, then reduced and only 3" going under the foundation. I ask if I could look inside at the plumbing, he said yes and went in with me. The house was all sheetrocked and painted. there was a bathroom group and then a clothes washer across the hall, it seemed pretty high. Out side through the roof there was only 2-2" vents through the roof, not enough to vent that plumbing. I ask him if he had a building permit, an electrical permit,, or a plumbing he said no to all the permits. He was a nice man and wantedd to comply. He said that Gene Sedick from St. Anthony Idaho did the plumbing and electrical work. His phone # is 208- 251- 3589 The addition is about 17' x 32' In the exiting cabinfrom 1948 the kitchen just drais outside on the ground,
			(6/18/2015 8:24 AM CHA)
			The reason I went to the job was to look at a sewer line PERMIT # WEB1506-01049
			(6/18/2015 8:26 AM CHA)
			I called Adam Bowcutt, and sent him the imformation in an e-mail. 18 June 2015
	06/15/2015	ADMIN TIME	(6/15/2015 11:23 AM CHA)
	06/15/2015		15 June 2015 FLAT TIRE Les Schwab in St Anthony to repair screw in the right rear tire no charge
			(6/12/2015 9:59 AM CHA)
	06/12/2015	ADMIN TIME	12 June 2015
	06/12/2015		Car wash at RAYS in Rexburg \$9.00
			(5/27/2015 8:26 AM CHA)
	05/27/2015	ADMIN TIME	26 May 2015
	05/27/2015		Ashton city police chief Tom Mattingly brought to my house the police report from 18 may 2015 from the neighbor backing into the 2012 Ford escape it hit the side door on the front passanger side.
			27 May 2015
			I E-mailed a copy to Adam Bowcutt. Then I went to the Ashton post office and mailed a hard copy t oAdam Bowcutt at 1515 east lincoln road Idaho Falls, Idaho 83401

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00008 05/01/2015
05/01/2015

ADMIN TIME

(5/1/2015 3:23 PM CHA)
New house
Turn at stoddard road, north of Spencer. From the freeway headed east for 5.3 miles, a brown gate on the south side of the road, a key is under a rock by the west railroad tie.
The garmin took me through kilgore, it was a long ride. Porcupine pass is a long road that reaches 7000 ft. It was 180 miles round trip. When a person goes take the freeway its faster. Beautiful country.

CURT BINGHAM

12

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00009	05/20/2015			(5/27/2015 8:19 AM CBI)
	05/20/2015			licenses for t square power in filer on solar system.kyle mabey-#a021918,george stanton-#j018213,bradley hallman-#a022934,justin pickford-#a022651,thaniel bishop #j017330
	05/13/2015			(5/14/2015 7:00 AM CBI)
	05/13/2015			working on ele1505-0054. owners name william walker at 2943 e3400 n twin falls finding report.pictures ect
	05/11/2015			(5/12/2015 6:56 AM CBI)
	05/11/2015			met with inspectors ,kevin and compliance cordinator in shoshone
	05/11/2015			(5/12/2015 6:59 AM CBI)
	05/11/2015			at request of city of twin falls bldg dept and tf county sherrifs dept. met with them at 2943 e 3400 n to look at their concerns with wiring on property
	06/11/2015			(6/11/2015 8:58 AM CBI)
	06/11/2015			did a noc on ele1504-00216 to idaho dept of transportation.
	04/29/2015			(4/30/2015 7:03 AM CBI)
	04/29/2015			meeting -pocatello
	06/25/2015			(6/29/2015 7:26 AM CBI)
	06/25/2015			evengreen electric has a problem with me calling them on 2 items on a technical assistant correction notice on permit #web1506-02245. corrections needed were breaking neutral at disconnect for isolating solar system.and to many grounds under a lug. i told ryan evengreen electric tto call mick willaims and if he wanted to let it go i would cancel cn.mick talked to ryan and told him we'd let it go this time but don't do it again.so i will cancel cn as per mick willaims
	06/30/2015			(7/2/2015 7:23 AM CBI)
06/30/2015			went thru a couple subdivision where new const under way in city of twin falls checking on contractors	

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00009	05/12/2015 05/12/2015	(5/13/2015 7:34 AM CBI) checked 2 licences at 3700n 1679 e twin falls. hank williams-j020348, justin beeson-a-o15475
	04/06/2015 04/06/2015	(4/7/2015 7:04 AM CBI) had vehicle serviced
	05/19/2015 05/19/2015	(5/20/2015 7:08 AM CBI) worked on permits for irrigation and pivots with electrical contractors and stanley trenching. trying to get every one on same page.ect
	06/02/2015 06/02/2015	(6/3/2015 6:58 AM CBI) took mandatory harassment online class

DAN LACHAPELLE **11**

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00010	06/25/2015 06/25/2015		COMPLIANCE	(6/29/2015 9:11 AM DLA) Carded Mark C. Hall 007437
	06/05/2015 06/05/2015		COMPLIANCE	(6/9/2015 9:46 AM DLA) Carded Robin M. Lillis card number 002214 exp. 8-31-15
	05/27/2015 05/27/2015		COMPLIANCE	(5/28/2015 8:29 AM DLA) Carded Clinton M. Hoover Lic. 015771 Exp. 6-30-18 Hallmark Heating and Cooling 208-704-5538 (Goodman) on 5-27-15
	04/02/2015 04/08/2015		COMPLIANCE	(4/7/2015 9:12 AM DLA) At 6005 W. Meadowbrook I carded employees for R&R Heating Ricardo Aguayo Exp App-020650 8-31-19 and Nicholas D. Bellomy App 014390 Exp. 12-31-17
	06/05/2015 06/05/2015		ADMIN TIME	(6/9/2015 9:21 AM DLA) Unlawful Harassment Prevention
	06/05/2015 06/05/2015		COMPLIANCE	(6/9/2015 9:37 AM DLA) Carded Ira Lee at 16941 E. Perimeter Rd Athol with Lakeside Custom Plumbing Card number Plb J-3661 Exp 3-26-16
	06/05/2015 06/05/2015		COMPLIANCE	(6/9/2015 9:41 AM DLA) Carded Cody Siegel at 19576 S.Loffs Bay Rd. Cda Lic. number Hvc app. 018800 exp 2019
	06/25/2015 06/25/2015		COMPLIANCE	(6/29/2015 9:04 AM DLA) I instructed bisseel plumbing how to install a tempering valve for an application in a residence.

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00010	06/25/2015 06/25/2015	COMPLIANCE	(6/29/2015 9:06 AM DLA) Carded John A. Haskew Lic # 022023 Exp. 2-28-20.
	06/25/2015 06/25/2015	COMPLIANCE	(6/29/2015 9:09 AM DLA) Carded K. Deleonard Lic. 021993 Exp. 2020
	06/09/2015 06/09/2015		(6/10/2015 7:55 AM DLA) Oil change on DBS 226

DAN STROUSE **12**

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1503-00002	06/09/2015 06/09/2015		COMPLIANCE	(6/10/2015 8:08 AM DST) I 90 wiegh in motion project, Post Falls. Quality Electric
	06/08/2015 06/08/2015		ADMIN TIME	Timothy Proctor ELE-J-14259, 4/30/17 exp. Jose Lopez 017765, 1/31/17 (6/9/2015 8:35 AM DST) Inspector Test 2hr, Travel to and from 2hr. Test location N end Spokane
	06/29/2015 06/29/2015		COMPLIANCE	(6/30/2015 8:27 AM DST) Bradley Salie J-004595 9/30/17
	04/17/2015 04/17/2015		ADMIN TIME	(4/21/2015 8:20 AM DST) Study for test, test questions from Caria.
	06/10/2015 06/10/2015		ADMIN TIME	(6/11/2015 8:29 AM DST) Mike Davis trak-it training
	06/15/2015 06/15/2015		COMPLIANCE	(6/15/2015 8:30 AM DST) Zach Mclean- 018705 , Journeyman Christopher Briggs- 019490 ,Journeyman
	06/19/2015 06/19/2015		COMPLIANCE	(6/19/2015 7:40 AM DST) Chad McCulley 008832 3/31/17
	04/08/2015 04/08/2015		ADMIN TIME	(4/9/2015 8:33 AM DST) 2hrs Avista utility meeting

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1503-00002	04/29/2015 04/29/2015	ADMIN TIME	(5/1/2015 7:48 AM DST) 4hr inspectors meeting
	06/03/2015 06/03/2015	ADMIN TIME	(6/9/2015 8:58 AM DST) 1hr harassment training
	06/29/2015 06/29/2015	COMPLIANCE	(6/30/2015 8:29 AM DST) Eric Zotti 015564- 5/13/18
	05/13/2015 05/13/2015	ADMIN TIME	(5/14/2015 8:37 AM DST) Test time 2hr, travel 2hr

DAVID SHERIDAN

14

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00056	05/07/2015 05/07/2015		ADMIN TIME	(5/8/2015 8:23 AM DSH) 2 hours travel to and from testing facility. 2 hours for Electrical Inspectors exam.
	06/02/2015 06/02/2015		ADMIN TIME	(6/9/2015 8:52 AM DSH) one hour for sexual harassment prevention training.
	04/14/2015 04/14/2015		COMPLIANCE	(4/14/2015 3:20 PM DSH) Energized Electric at Kootenai Medical Center addition, on 4/10/15: Kenneth E Gifford - J - 020994 - exp 11/30/17 Matthew Macisaac -J - 022166 - exp 2/28/18 Cameron Jeffs - J - 017672 - exp 8/31/17 Benjamin Olson - A - 022167 - exp 2/28/20 Justin M Huber - A - 022535 - exp 4/30/20 Terry Huber - A - 022534 - exp4/30/20
	06/09/2015 06/09/2015		COMPLIANCE	(6/10/2015 7:43 AM DSH) 7400 Mineral Drive - VTI Brice Vineyard - 005759 (journeyman)
	06/09/2015 06/09/2015		COMPLIANCE	(6/10/2015 7:45 AM DSH) 7400 Mineral Drive - RK electric Darrell Sheridan - ELE-J-28986
	06/10/2015 06/10/2015		ADMIN TIME	(6/11/2015 8:28 AM DSH) Trakit refresher training w/ Mike Davis.

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00056	04/14/2015		COMPLIANCE	(4/14/2015 3:31 PM DSH)
	04/14/2015			Energized Electric at Kootenai Medical Center addition, on 4/10/15:
				Ryan Murbach - J - 001935 - exp 12/31/17
				Eric Hanlin - J - 021859 - exp 4/30/18
				Brice Thornton - ELE-J-23771 - exp 6/30/16
				Eric Olson - ELE -J-5725 - exp 8/31/16
				Randy Brown - A - 021837 - exp 2/28/20
				Frank Erickson - ELE-J-13784 - exp 9/30/17
	04/14/2015		COMPLIANCE	(4/14/2015 3:26 PM DSH)
	04/14/2015			Energized Electric at Kootenai Medical Center addition, on 4/10/15:
				Mica J Kunkel - J - 006758 - exp 5/31/16
				Matt Kidder - J - 018212 - exp 4/30/17
				William Dewey - A - 021040 - exp 10/31/19
				Benjamin Krauss - A - 021951 - exp 1/31/20
			Scott McLuskie - J - 000711 - exp 8/31/15	
			David Bouchard - J - 017014 - exp 9/30/16	
04/17/2015		ADMIN TIME	(4/20/2015 7:48 AM DSH)	
04/17/2015			2 hours spent on exam prep.	
04/29/2015		ADMIN TIME	(4/30/2015 7:47 AM DSH)	
04/29/2015			4 hour inspectors meeting. 8-12.	
04/08/2015		COMPLIANCE	(4/9/2015 7:50 AM DSH)	
04/08/2015			Coeur dAlene Electric on Macgrath road.	
			Caleb Carlyle - 021379 - Exp 11/30/19	
			Paul Welter - ELE-J-15987 - Exp 11/30/16	
04/08/2015		ADMIN TIME	(4/9/2015 7:45 AM DSH)	
04/08/2015			2 hour Avista Utilities meeting.	
04/15/2015		ADMIN TIME	(4/16/2015 8:06 AM DSH)	
04/15/2015			one hour tech assist at 311 N CdA St. with Sawyer plumbing and electric.	
06/09/2015		COMPLIANCE	(6/10/2015 7:42 AM DSH)	
06/09/2015			7400 Mineral Drive - Sawyer Plumbing	
			Nick Whiting - PLB-J-3851	
			Leslie Dougall - 12501 (apprentice)	

DICK SIVEY

8

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00012	05/18/2015 05/18/2015		ADMIN TIME	(5/18/2015 2:48 PM DSI) went to Les Schwab to have tire fixed

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00012	05/18/2015	COMPLIANCE	(5/18/2015 2:52 PM DSI)
	05/18/2015		stopped at Old Town Conv. store to check permits and license's no one was there doing electrical but was told that Kortney Bennett was doing work. He is not licensed and is not a contractor, told them he cannot do any work at all and to stop doing any electrical demo
	04/29/2015	ADMIN TIME	(4/29/2015 6:20 PM DSI)
	04/29/2015		drove to Meridian office for inspectors meeting, drove back to McCall
	04/01/2015	COMPLIANCE	(4/1/2015 3:47 PM DSI)
	04/01/2015		stopped 202 River st. to check permits and status of house addition. No permits have been taken and owner did not know he needed permit. I told him how and where to go to get elect. plumbing and hvac permits.
	06/17/2015	PASS	(6/17/2015 5:17 PM DSI)
	06/17/2015		met with All American Cascade at 145 Divide Rd. in Round Valley for walk thru house for home owner to go over requirements to finish house
	06/16/2015	PASS	(6/17/2015 5:22 PM DSI)
	06/16/2015		went to Les Schwab to have tire on car inspected. called Randy, Shawna and Ron about damage on tire, got 4 new tires installed
	04/16/2015	ADMIN TIME	(4/16/2015 3:58 PM DSI)
	04/16/2015		Had Les Schwab swap snow tires back to regular tires
	06/16/2015	PASS	(6/17/2015 7:10 AM DSI)
	06/16/2015		went to Les Schwab tires to have tire checked tire was coming apart on side wall, ended up had to replace all 4 tires talked to Randy, Shawna and Ron

DON GEIGER **8**

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00013	06/23/2015		ADMIN TIME	(6/24/2015 7:53 AM DGE)
	06/23/2015			go over job with Josh from amp electric
	04/14/2015		ADMIN TIME	(4/15/2015 7:41 AM DGE)
	04/14/2015			fighting with persi sign in. calls to boise. sign up for class in june.
	06/10/2015		ADMIN TIME	(6/12/2015 7:51 AM DGE)
	06/10/2015			persi class

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00013	04/03/2015 04/03/2015	ADMIN TIME	(4/6/2015 7:44 AM DGE) met w cont go over service re locate
	04/29/2015 04/29/2015	ADMIN TIME	(4/30/2015 7:44 AM DGE) code class with mick
	04/07/2015 04/07/2015	ADMIN TIME	(4/8/2015 7:35 AM DGE) greg with r c worst go over job at lake cabin
	06/09/2015 06/09/2015	ADMIN TIME	(6/10/2015 7:58 AM DGE) lic chk
	04/08/2015 04/08/2015	ADMIN TIME	(6/10/2015 8:00 AM DGE) scott austin--23013 dale g. burge --17208---parker elect. hwy 95 & govt. way se corner (4/9/2015 7:14 AM DGE) avista meeting

GARY SONNEN **13**

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00016	06/17/2015 06/17/2015		COMPLIANCE	(6/18/2015 7:28 AM GSO) Garrett Mills HVAC A 021960
	06/03/2015 06/03/2015		COMPLIANCE	(6/4/2015 7:40 AM GSO) Jonathon J Chase 014631 1/31/18
	06/08/2015 06/08/2015		FAIL (ELE)	(6/9/2015 8:40 AM GSO) Lawrence Newman PLB J 3689 6/30/16
	06/03/2015 06/03/2015		COMPLIANCE	(6/4/2015 8:00 AM GSO) Ron Riggs j 2979 5/31/17
	04/22/2015 04/22/2015		COMPLIANCE	<<GSO:1504280858030001>>
	06/23/2015 06/23/2015		COMPLIANCE	(6/24/2015 7:35 AM GSO) Check out job on Quaking Aspen, reports of no J man supervision, only escivators at site.

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00016	06/17/2015	COMPLIANCE	(6/18/2015 7:26 AM GSO)
	06/17/2015		Ken Benson HVAC J 3759
	06/17/2015	COMPLIANCE	(6/18/2015 7:27 AM GSO)
	06/17/2015		Colt Lawless HVAC A 018734
	06/03/2015	COMPLIANCE	(6/4/2015 7:37 AM GSO)
	06/03/2015		Lorne Scott Hanks ele j 23684 8/31/15
	05/28/2015	COMPLIANCE	(5/29/2015 8:41 AM GSO)
	05/28/2015		Ryan Waters J 013468 8/31/15
	05/28/2015	COMPLIANCE	(5/29/2015 8:42 AM GSO)
	05/28/2015		Dann Waters SJ 1307 8/31/16
	04/29/2015	ADMIN TIME	(5/1/2015 7:26 AM GSO)
	04/29/2015		Electric inspector meeting
	06/03/2015	COMPLIANCE	(6/4/2015 7:38 AM GSO)
	06/03/2015		Kenneth Anthont a 005905 3/31/20

GARY WILLIAMS

8

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1505-00002	06/30/2015		ADMIN TIME	(7/1/2015 8:24 AM GWI)
	06/30/2015			HVAC study
	06/29/2015	1505-2195	ADMIN TIME	(6/30/2015 8:31 AM GWI)
	06/30/2015			HVAC Exam study
	06/22/2015		ADMIN TIME	(6/23/2015 8:22 AM GWI)
	06/22/2015			Compliance
	06/08/2015		ADMIN TIME	(6/9/2015 9:37 AM GWI)
	06/08/2015			completed unlawful harrasment prevention class
	06/08/2015		ADMIN TIME	(6/9/2015 9:38 AM GWI)
	06/08/2015			office work

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00017	05/06/2015	PASS W/CONDITIONS		(5/6/2015 6:23 PM GRO)
	05/06/2015			meet with kevin and superior elect in fruitland to go through gutter fill and other violations 4 HRS
	05/11/2015	COMPLIANCE		this permit # ele1504-00220
	05/11/2015			(5/11/2015 5:14 PM GRO) lic check emmett stephens elect 1- fernando guadarrama ele-a-32921 2-ryan hasenyager ele-j-014512 3-jose esquivel ele-a-29161

GINO ENDO **1**

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00018	06/19/2015 06/22/2015	verification	COMPLIANCE	<p>(6/22/2015 9:12 AM GEN)</p> <p>I was called by George Guardipee, 6/17/15, the Fort Hall building inspector about a job that was being done on the reservation. He thought Dykes Electric of Pocatello was doing electrical work without a permit. He said he thought I would need to write them a notice of violations on no permit and no inspection. He said the job was on Schiller Rd and was for the Bureau of Indian Affairs. I stopped thursday , 6/18/15, at Dykes Electric shop and talked to the people who were working on this job. They said they did not know they were suppose to have trespassing permits and buisness license through the tribe. They have worked on the reservation for years and have never had to get these things until George was hired. These are not the first contractor to say this to me, I don't know if the tribe has sent notification to the contractors so they would know they were in violation of tribal law. After talking to Dykes about what they were doing, they were not actually doing electrical work, they were only pulling out a pump and taking it to the shop for repair. The electric motor was never unhooked, only the shaft was uncoupled for removal. After it was repaired, they did loosen the bolts to the motor to aline the shaft, but did not do any electrical work. They may have hung a lock and tag, but did not disconnect or hook anything up. I went to the job site on Schiller road and looked things over, 6/19/15, you could clearly see what was worked on. Dykes Electric does alot of pump panel work for various farmers, and has always took out permits with the state. My findings for this job is that Dykes does not need any electrical permit for the work that was done. I have pictures on my phone to verify what was worked on. I also believe Dykes has gotten there buisness license, and trespassing permits. NO ACTION TAKEN</p> <p>(6/26/2015 9:05 AM GEN) PPP</p>

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

JAKE WOOD **1**

<u>Permit No</u>	<u>Scheduled Date Completed Date</u>	<u>Remarks</u>	<u>Result</u>	<u>Notes</u>
VER1501-00020	05/20/2015 05/20/2015		COMPLIANCE	License check Shane Farwell J-27204 8317 snohomish

JASON GUERBER **20**

<u>Permit No</u>	<u>Scheduled Date Completed Date</u>	<u>Remarks</u>	<u>Result</u>	<u>Notes</u>
VER1501-00021	05/12/2015 05/12/2015		ADMIN TIME	(5/12/2015 8:42 PM JGU) Recieved manuals J, D, and S training from Darren McRae.
	05/11/2015 05/11/2015		ADMIN TIME	(5/11/2015 10:40 PM JGU) Attended meeting in Shoshone ran by Terry Blessing with other inspectors from central Idaho area. The subject of the meeting was on compliance throughout the state.
	06/02/2015 06/02/2015		ADMIN TIME	(6/2/2015 6:36 PM JGU) Worked on sexual harassment course.
	04/09/2015 04/09/2015		ADMIN TIME	(4/10/2015 10:06 AM JGU) Attended HVAC code update class at Hailey City Hall put on by Jerry Peterson. The class was 4 hours.
	04/21/2015 04/21/2015		ADMIN TIME	(4/24/2015 8:53 AM JGU) Performed phone interview for Region 1 Plumbing/ HVAC Supervisor position.
	04/13/2015 04/13/2015		ADMIN TIME	(4/13/2015 8:58 PM JGU) Went to Shoshone to meet with new supervisor Adam Bowcutt, Kevin Gellings, and the other inspectors from what was formerly called Region 2B.
	06/12/2015 06/12/2015		ADMIN TIME	(6/12/2015 9:47 AM JGU) Spent 1 1/2 hours working on results on the 65 inspections performed on 6/11/15.
	06/24/2015 06/24/2015		COMPLIANCE	(6/24/2015 7:20 PM JGU) Performed compliance at 214 S River St in Hailey. Mike Menkee...HVC-J-5046 and Ferd Saunders Jr...PLB-J-12164
	06/05/2015 06/05/2015		ADMIN TIME	(6/5/2015 8:26 AM JGU) Went to Blaine County Building to introduce myself to the new interim building inspector Hermie Haavik

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00021	06/08/2015 06/08/2015	ADMIN TIME	(6/8/2015 9:40 PM JGU) Met with other inspectors in Shoshone
	04/30/2015 04/30/2015	COMPLIANCE	(5/1/2015 9:55 AM JGU) Saw an HVAC worker I did not recognize so I checked his card at 136 Clos Du Val in Sun Valley. Robert Richards...HVC-A-015285
	04/23/2015 04/23/2015	ADMIN TIME	(4/24/2015 8:55 AM JGU) Met with general contractor, plumber, and excavator to discuss sewer. tie in for airport operations building. gave okay for contractor to witness test so sewer line can be backfilled to a safe elevation.
	06/08/2015 06/08/2015	ADMIN TIME	(6/8/2015 9:42 PM JGU) At the request of Hailey Building Inspector Jim Lynch, stopped by 311 Apache in Hailey to look at an issue the lot had with a sewer stub provided by the city that was backgrading.
	05/26/2015 05/26/2015	ADMIN TIME	(5/26/2015 7:29 PM JGU) Picked up office supplies at Jane's Artifacts. Also restocked inspection stickers at office.
	04/28/2015 04/28/2015	ADMIN TIME	(4/28/2015 7:32 PM JGU) Went to check on new airport addition to make sure they could keep the flow of the job going. I am concerned because the airport is shut down until job is complete. The generals for Conrad Brothers said they will keep me in the loop.
	05/28/2015 05/28/2015	COMPLIANCE	(5/29/2015 9:47 AM JGU) Performed compliance at 101 Diamondback Rd in Sun Valley. Stephen Jurgensmier...PLB-J-008510, Richard Cortez...PLB-A-010638, and Corby Billups...PLB-A-013505
	04/14/2015 04/14/2015	ADMIN TIME	(4/14/2015 7:46 PM JGU) Dropped off flyers to supply houses as requested by John Neilson
	05/26/2015 05/26/2015	ADMIN TIME	(5/26/2015 7:28 PM JGU) Dropped off flyers at supply houses for contractor meeting in Twin Falls on June 11th.
	06/24/2015 06/24/2015	COMPLIANCE	(6/24/2015 7:21 PM JGU) Performed compliance at 218 Elkhorn Rd in Sun Valley. Jeff Schroeder...PLB-J-11449 and PLB-C-12196
	04/28/2015 04/28/2015	COMPLIANCE	(4/28/2015 7:30 PM JGU) Visited a residence on Bay Horse Drive in Bellevue after a tip from a plumber that some water lines had been installed incorrectly with unapproved material. I went to investigate and discovered the material was okay due to the fact that it was 200 lb poly to a horse waterer in a barn.

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

JEFF ANDERSON

24

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00022	05/04/2015 05/04/2015	1406-01933	COMPLIANCE	(5/4/2015 2:52 PM JAND) kyle r pettyman j-022086 2/28/18
	06/10/2015 06/10/2015		ADMIN TIME	(6/15/2015 7:32 AM JAND) inspector test in spokane
	05/14/2015 05/14/2015		ADMIN TIME	(5/14/2015 7:52 AM JAND) have a 9:45 am appointment at rokstad ford to trouble shoot why engine warning light stays on
	04/15/2015 04/16/2015		COMPLIANCE	(4/16/2015 8:12 AM JAND) i was contacted by JE electric of possible un-licence electrician, contractor doing work at Winter Ridge. i stopped by and talked to manager, she confirmed work was being done to the kitchen area and that the electrician was licenced for contracting and working. i gave her a card and told her i wanted to talk to electrician and wanted to see permit. no permit as of 4/16/15 @ 7:10 am PT
	05/14/2015 05/14/2015		COMPLIANCE	(5/18/2015 7:54 AM JAND) jacob mc donald a020338 8/31/19 daniel noren j24860 10/31/17
	05/13/2015 05/13/2015		ADMIN TIME	(5/14/2015 7:50 AM JAND) met with mike and larry from mike's electric and talked about flour mill job in BF
	06/30/2015 06/30/2015		ADMIN TIME	(7/2/2015 7:48 AM JAND) met with staff in cda
	05/20/2015 05/20/2015		ADMIN TIME	(5/20/2015 8:34 AM JAND) take inspector test in spokane
	05/04/2015 05/04/2015		ADMIN TIME	(5/4/2015 2:59 PM JAND) stopped in to get tire rotation at 99,970
	05/04/2015 05/04/2015		ADMIN TIME	(5/4/2015 2:58 PM JAND) stopped in to get oil changedat 99,970
	04/30/2015 04/30/2015		ADMIN TIME	(4/30/2015 6:41 PM JAND) mark from avista wanted me to stop by 202 1/21st ave sandpoint and look at feeders to see if there was a problem. i did not find anything wrong so i called him back and left a message asking if i could be at wrong address. i'll talk with him next week

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00022	04/09/2015		ADMIN TIME	(4/9/2015 4:57 PM JAND)	
	04/13/2015			9 am meeting with avista and banco at 1110 superior (yellow/tan building)	
		1406-01933			
	04/08/2015		COMPLIANCE	(4/9/2015 8:39 AM JAND)	
	04/08/2015			miles pearsal ele-a-32831 6/30/17	
				dave melius ele-j-15673 12/13/17	
	04/15/2015		COMPLIANCE	(4/15/2015 8:08 AM JAND)	
	04/15/2015			stopped by popey's there is a permit on site	
				web 1504-01014 action electric	
	04/07/2015		COMPLIANCE	(4/8/2015 8:02 AM JAND)	
	04/07/2015			stopped by popey's bar in priest river. owner was not there, left	
				buisness card. requested a call back to talk about possible work	
				done with out permits. checked passed work and found	
				permit:web1205-00458. i will give owner a couple days to	
				respond, if i do not here back i'll make anouther visit.	
	06/10/2015		ADMIN TIME	(6/15/2015 7:30 AM JAND)	
06/10/2015			trakit training		
06/18/2015		COMPLIANCE	(6/18/2015 4:04 PM JAND) kevin		
06/18/2015			kuhn ele-j-13358 9/30/16 wyatt		
			hopper ele-a-016725 9/30/18		
04/29/2015		ADMIN TIME	(5/4/2015 7:38 AM JAND)		
04/29/2015			meeting with Mick Williams		
04/20/2015		COMPLIANCE	(4/21/2015 8:36 AM JAND)		
04/20/2015			Michael Jochim ele-j-6984 10/31/15		
04/20/2015		ADMIN TIME	(4/21/2015 8:34 AM JAND)		
04/20/2015			went to The Wireless Works to repair cell phone		
05/19/2015		ADMIN TIME	(5/20/2015 8:32 AM JAND)		
05/19/2015			went to rokstad ford for car repair		
04/08/2015		COMPLIANCE	(4/9/2015 8:05 AM JAND)		
04/08/2015			talked to owner of popeys bar		
			action elec. just started job		
			called rich and he confirmed		
			lots of work to do still and permit will be bought		
			when job starts		
06/15/2015		ADMIN TIME	(6/15/2015 4:46 PM JAND)		
06/15/2015			met with Gary today to go over past permits and evaluation		

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00022	05/04/2015 05/04/2015		ADMIN TIME	
		1406-01933		(5/4/2015 2:57 PM JAND) stopped over at 202 1/2 1st in sandpoint by avista's request. bldg has 3 tenants sharing 1 meter. avista recieved a request by owner to investigate usage of power.

JEFF OAKES **5**

Permit No	Scheduled Date Completed Date	Remarks	<u>Result</u>	Notes
VER1501-00023	06/01/2015 06/01/2015		COMPLIANCE	(6/1/2015 2:21 PM JOA) Had a phone call about a non permitted job at 860 hwy 32, with a non licensed person doing the electrical work. I went to 860 hwy 32, there is a shop going up, Fremont county permit #Bp15-026 There was know one on the job site. The electrical work is almost done, I will check again
	04/22/2015 04/22/2015		ADMIN TIME	(4/22/2015 2:14 PM JOA) oil change 1 hr ford repare shop 2 hr
	06/02/2015 06/02/2015		ADMIN TIME	(6/2/2015 2:52 PM JOA) sexual harassment class
	04/29/2015 04/29/2015		ADMIN TIME	(4/29/2015 7:27 AM JOA) electrical inspector meeting all day
	04/03/2015 04/03/2015		ADMIN TIME	(4/3/2015 11:30 AM JOA) cheked on byu job going goo study 517 for up coming job

JIMMIE STANSELL **14**

Permit No	Scheduled Date Completed Date	Remarks	<u>Result</u>	Notes
VER1501-00025	06/10/2015 06/10/2015	License Verification	COMPLIANCE	(6/15/2015 1:01 PM JST) While doing inspections in Biltmore Subdivision I check the license of the following individuals doing a rough-in at 504 Tall Prairie. MP Elec. Aldin Dizdarevic ELE-A-013453 Exp. 8/31/17 Cedo Borak ELE-J-25794 Exp. 12/31/17 Denis Dizarevic ELE-A-017093 Exp. 10/31/18 Cerimovic Fikret ELE-A-0117341 Exp. 11/30/18 Patrick Willet ELE-J-22596 Exp. 4/30/18

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00025	05/29/2015	License Verification	COMPLIANCE	(6/1/2015 2:31 PM JST)
	05/29/2015			While making a random stop in Chesterfield Sub, Meridian I checked the license of the following individuals roughing in a house.
				Powerhouse Elec. Jacob Moore ELE-J-001383 Exp. 5/31/18 Sergio Uribe ELE-A-017170 Exp. 10/31/18 Joe Richardson ELE-A-22716 Exp. 8/31/19 (6/19/2015 2:33 PM JST)
	06/19/2015	License Verification	COMPLIANCE	While doing a Final Inspection in Shepard Creek Sub, Meridian I check the license of the following individuals.
	06/19/2015			Powerhouse Electric Jeff Leas ELE-J-16550 Exp. 2/28/18 Conner Tocheri ELE-A-019282 Exp. 6/30/19 (6/3/2015 1:00 PM JST) I stopped at 1167 E Radiant Ridge Dr, Meridian and checked the license of the following individuals who where doing a rough-in of a new house.
	06/03/2015	License Verification	COMPLIANCE	Extreme Electric Michael Hamilton ELE-J-32448 Exp. 6/30/17 Dustin Boren ELE-A-016565 Exp. 8/31/18 Daniel Finnegan ELE-A-003903 Exp. 4/30/20 (4/9/2015 2:36 PM JST)
	06/03/2015			While doing a Rough-in Inspection at 3045 E St Lukes St, Meridian I checked the license of the following individuals.
	04/06/2015	License Verification	COMPLIANCE	Robert Eames ELE-H-20308 Exp. 9/30/15 Steven Cody Lott ELE-M-16691 Exp. 8/31/17
	04/06/2015			

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

Inspection ID	Date	Category	Findings/Status	Inspector/Notes
VER1501-00025	06/09/2015	License Verification	FINDINGS	(6/16/2015 3:07 PM JST) While doing a rough-in inspection for a restroom remodel at 2829 S Givens Wy, Meridian.
	06/09/2015			I was met by the General Contractor and he started the explaining the electrical wiring and outlets to me. When asked if he did the electrical work he replied yes. When asked if he was a licensed electrical contractor or a licensed electrician, he replied no to both. I informed him to cease all electrical work, that he was not allowed to do any electrical work, except on his personnel residence in which he lives in. I gave him a verbal warning and informed him any further violations/infractions would result in a NOV and fines. I required him to hire an electrical contractor, they will be required to pull a permit, and they are required to call in for inspections. Sublime Elec. was hired, verified the work done and made corrections as needed. I know of no other verbal warnings or violations for this individual General Contractor for the project Herb Fitzpatrick Handy Herb Services 400 S Highland Middleton, ID 83644 herbfitzpatrick@msn.com 208-991-7657 (6/30/2015 2:32 PM JST) I checked the license of the following individuals doing a rough-in in Kentucky Ridge Estates at 1090 W Contender, Meridian. Glenn Electric Miguel Cortes ELE-J-29989 Exp. 4/30/18 Ronald Campbell ELE-J-32533 Exp. 8/31/17 Charles Cavin ELE-A-020668 Exp. 8/31/19 Jacob Ballard ELE-A-35417 Exp. 9/30/17 David Kuhn ELE-A-21420 2/28/20 (6/1/2015 2:26 PM JST) While doing a Rough-in Inspection at 700 E Franklin, Meridian I checked the license of: Timothy Watkins ELE-J-22148 Exp.1/31/17 (6/1/2015 2:38 PM JST) While doing a underground and temp service at 920 W Kodiak, Meridian I check the license of the following individuals: Rocky Mountain Elec. Tobias Ames ELE-J-20656 Exp. 7/31/15 Victor Molina ELE-A-016892 Exp. 9/30/18 Chad G Brunton ELE-A-018488 Exp. 4/30/17
	06/29/2015	License Verification	COMPLIANCE	
	06/29/2015			
	05/29/2015	License Verification	COMPLIANCE	
	05/29/2015			
	06/01/2015	License Verification	COMPLIANCE	
	06/01/2015			

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00025	04/29/2015	License Verification	COMPLIANCE	(4/30/2015 2:32 PM JST) While doing an Underground Inspection for the apartments going in at Tech Ln, Meridian I checked the licenses of the following:
	04/29/2015			
	04/29/2015	License Verification	COMPLIANCE	Bryon Sutherland ELE-J-25965 Exp. 10/31/16 Spencer J Walgamott ELE-A-017426 Exp. 11/30/18 Richard Ramsey ELE-J-4848 Exp. 6/30/17 (4/30/2015 2:27 PM JST) While doing a Final Inspection at 2219 E Lattice, Meridian I checked the lincses of the following:
	04/29/2015			
	05/11/2015	License Verification	COMPLIANCE	Christopher Husted ELE-J-29862 Exp. 3/31/18 (5/13/2015 12:12 PM JST) While doing a Rough-in Inspection at 1075 S Wells, Meridian I checked the license of the following individuals with Winters Elec.
	05/11/2015			
	04/10/2015	License Verification	COMPLIANCE	August Basile ELE-J-12500 Exp. 10/31/15 Christopher L Martin ELE-A-016927 Exp. 9/30/18 (4/16/2015 2:22 PM JST) I stopped by 4158 S High Cliff, Meridian and checked the license of the following individuals doing a electrical rough-in.
	04/10/2015			MP Electric
	04/27/2015	License Verification	COMPLIANCE	Cedo Borak ELE-J-25794 Exp. 12/31/17 Patrick Villet ELE-J-22596 Exp. 4/30/15 Aldin Dizdarevic ELE-A-013453 Exp. 8/31/17 Dennis Dizdarevic ELE-A-017093 Exp. 10/31/18 (4/30/2015 2:24 PM JST) While doing a Rough-in Inspection at 400 W Overland, Meridian I checked the license of:
	04/27/2015			Pierre Elskamp ELE-J-38878 Exp. 8/31/17

JOSH NYMAN

13

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00055	04/29/2015		COMPLIANCE	(4/29/2015 4:36 PM JNY) Jacob D Thurgood ELE-Journeyman 018163 EXP 3-31-17
	04/29/2015			
	04/21/2015		ADMIN TIME	Justin Haslam ELE-Journeyman 018164 EXP 3-31-17 (4/21/2015 4:54 PM JNY) Took the practice tests for the 2012 IMC commercial inspector tests. Took the test 4 times and got a 74%,82%,84%,and 88%. They were the timed version
	04/21/2015			

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

Inspection ID	Date	Inspector	Activity	Notes
VER1501-00055	05/18/2015		ADMIN TIME	(5/18/2015 4:18 PM JNY)
	05/18/2015			Studying For the Commercial HVAC inspector test.
	04/29/2015		ADMIN TIME	(4/29/2015 4:34 PM JNY)
	04/29/2015			Working with IT to get my printer issue fixed still not printing in Track-IT
	06/02/2015		ADMIN TIME	(6/2/2015 4:04 PM JNY)
	06/02/2015			Studied for the Commercial Mechanical Inspector test
	05/18/2015		ADMIN TIME	(5/18/2015 4:17 PM JNY)
	05/18/2015			Took the Commercial HVAC inspector test. Failed got 69% needed to get 75%
	04/08/2015	study HVAC	ADMIN TIME	(4/8/2015 4:17 PM JNY)
	04/08/2015			studying for the commercial inspector test
	06/03/2015		ADMIN TIME	(6/3/2015 4:16 PM JNY)
	06/03/2015			Studying for the Commercial Mechanical Inspector.
	04/28/2015		COMPLIANCE	(4/28/2015 4:07 PM JNY)
	04/28/2015			Went to McCain Foods today just to see if they had anything that needs to be brought to our attention. Left buisness card at the security check point to give to the plant manager. Arnold Ortiz ELE-J-16682 EXP 9-30-15 Darin Blair apprentice 016992 EXP 9-30-18 Kevin Rambow plumbing apprentice 020674 EXP 8-31-19 Jose G Castillo plumbing apprentice PLB-A-4766 EXP 10-31-16 they were picking up a work trailer on the job Alfred Ted Hall ELE-J-23065 EXP 6-30-15
06/11/2015		ADMIN TIME	Larry Hooper ELE-A-35926 7-31-19 (6/15/2015 4:17 PM JNY)	
06/11/2015			Attended the plumbing class that John had at CSI	
06/08/2015		ADMIN TIME	(6/8/2015 4:18 PM JNY)	
06/08/2015			Took the commercial mechanical inspector test Passed it	
05/27/2015		ADMIN TIME	(5/27/2015 4:25 PM JNY)	
05/27/2015			Studying for my Commercial Mechanical Test.	

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00055 04/28/2015
04/28/2015

ADMIN TIME

(4/28/2015 4:10 PM JNY)
working with IT to get my printer to work.

KEVIN HUBBLE

18

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00030	05/13/2015 05/13/2015	1503-01974	COMPLIANCE	(5/14/2015 8:02 AM KHU) aspen elec app james richard covey 009629 5/31/16 ,Kach Robinson 020121 7/31/19 JW rndre duckett 25980 6/30/17
	04/09/2015 04/09/2015		COMPLIANCE	(4/10/2015 7:41 AM KHU) edward j udry 008417 1-31-16 amped elec
	04/02/2015 04/02/2015		ADMIN TIME	(4/3/2015 6:56 AM KHU) 3 hr eye app Dr Tweetin
	05/06/2015 05/06/2015		COMPLIANCE	(5/7/2015 7:10 AM KHU) meeting with superior elec and edgewood spring creek Fruitland Geret robison present ckecking complaits
	06/01/2015 06/01/2015		COMPLIANCE	(6/1/2015 9:13 AM KHU) RICHARD BOLTON 021783 1/31/20
	06/08/2015 06/08/2015		COMPLIANCE	(6/8/2015 4:19 PM KHU) Kevin Kerner 24571 7-31-16 ,C-38670 6-30 15 ,Master 21716 12-31-17 . Works for LMS maintance on sticker statios
	06/11/2015 06/11/2015		COMPLIANCE	(6/18/2015 8:20 AM KHU) cHAD rILE yOUNGBLOOD 31393 1-31-16
	05/21/2015 05/21/2015		PASS	(5/22/2015 8:05 AM KHU) eye dr and iron infusion
	06/22/2015 06/22/2015		ADMIN TIME	(6/22/2015 4:06 PM KHU) Unlawful harassment Pervation on line course 2hrs
	04/15/2015 04/15/2015		COMPLIANCE	(4/17/2015 8:24 AM KHU) randy lynn maurer 12535 7-30-16 , john OVERFELT 18976 4-30--16
	05/15/2015 05/15/2015		COMPLIANCE	(5/15/2015 5:00 PM KHU) REYMUNDO TORRES 15344 1-31-18

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00030	06/05/2015		COMPLIANCE	(6/8/2015 4:14 PM KHU)
	06/05/2015			Spencer J Walcamont 017426 113016, Byron Sutherland J-25965 10-3-16
		1503-01974		
	04/29/2015		ADMIN TIME	(4/30/2015 7:18 AM KHU)
	04/29/2015			inspecters meeting
	05/08/2015		ADMIN TIME	(5/11/2015 8:37 AM KHU)
	05/08/2015			oil change car wash
	04/16/2015		COMPLIANCE	(4/17/2015 5:16 PM KHU)
	04/16/2015			call from Idaho Power renter dryer vent carrying current found tag broke (IPCO) indoor panel outside will have to find property owner for enforcement Fruitland Elec to fix by renter
				(4/17/2015 5:18 PM KHU)
				meter77 68 405 306 1/2 ates Ave Parma ID
	04/16/2015		COMPLIANCE	(4/17/2015 8:11 AM KHU)
	04/16/2015			Justin Carlson 010662 9-30-17 , Tyrel Short 006387 4-30-16
	04/22/2015		COMPLIANCE	(4/23/2015 7:58 AM KHU)
04/22/2015			david forbes 011895 6-30-17	
05/05/2015		COMPLIANCE	(5/4/2015 8:20 AM KHU)	
05/05/2015			non compliance Dan ans Abgela Richards 22000 Ten Davis Parma Idaho .Complate from Canyon County Bldg Dept new quest house no permits	
			(5/6/2015 7:12 AM KHU)	
			quest house along river old 2 story witha lot of add ons no wire ran left name and cardt owners home	

LARRY WHARTON

14

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00031	06/30/2015 06/30/2015		ADMIN TIME	
	06/17/2015 06/17/2015		ADMIN TIME	(6/17/2015 2:06 PM LWH) Work on uninspected permits.
	04/22/2015 04/22/2015		COMPLIANCE	(4/22/2015 12:51 PM LWH) Joshua Humphries J-011819 ok

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00031	04/08/2015	ADMIN TIME	(4/8/2015 3:42 PM LWH)
	04/08/2015		Wrote 6 Nov's
	04/09/2015	ADMIN TIME	(4/9/2015 2:23 PM LWH)
	04/09/2015		Time card and p card verification
	06/18/2015	ADMIN TIME	(6/18/2015 3:45 PM LWH)
	06/18/2015		Time sheet
	05/06/2015	PASS	(5/6/2015 3:04 PM LWH)
	05/06/2015		State car serviced, oil and filter
	04/06/2015	ADMIN TIME	(4/6/2015 4:53 PM LWH)
	04/06/2015		Worked on active permits and uninspected permits.
	06/04/2015	ADMIN TIME	(6/4/2015 2:04 PM LWH)
	06/04/2015		Meteing with city of Hailey on carnival.
	06/02/2015	ADMIN TIME	(6/2/2015 1:53 PM LWH)
	06/02/2015		SEXual herasment class.
	04/01/2015	ADMIN TIME	(4/1/2015 1:39 PM LWH)
	04/01/2015		A Valley pivot was built on the corner of Gannett Rd and Baseline Rd in Gannett with no permit i spent 2hrs reserching hew built and wired the pivot, and found that the Sprinkler Shop out of Paul Idaho built it and they were trying to find out hew wire the pivot and the underground and main disconnect for the pivot I have a witness that said they saw C&R ele. trucks in the field last fall working. No other info as yet. A RED TAG was placed on main disconnect to Pivot at 12:43 pm 4/1/15
05/11/2015	ADMIN TIME	(5/12/2015 8:38 AM LWH)	
05/11/2015		Compliance meeting Shoshone 3 hrs	
05/20/2015	ADMIN TIME		
05/20/2015			
04/22/2015	ADMIN TIME	(4/22/2015 12:47 PM LWH)	
04/22/2015		Working on active permits and uninspected permits1 1/2 hrs	

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

MARK BOREN **8**

<u>Permit No</u>	<u>Scheduled Date Completed Date</u>	<u>Remarks</u>	<u>Result</u>	<u>Notes</u>
VER1501-00033	06/02/2015 06/02/2015		COMPLIANCE	(6/3/2015 8:38 AM MBO) DISCUSSED ON SITE PLMG REQUIREMENTS WITH OWNER AND CONTRACTOR (NORTHERN STAR PLMG) AT 211 S. WASHINGTON, OLD TOWN .ALSO DISCUSSED MECH REQUIREMENTS FOR MECH WORK-SMALL RESTUARANT SERVICE VEHICLE
	06/25/2015 06/25/2015		ADMIN TIME	
	05/19/2015 05/19/2015		ADMIN TIME	(5/20/2015 8:26 AM MBO) Discussed sewer issue at UPS store on Cedar St. in Sandpoint with Mike Hammack from Aqua Plg. and Don Carter ,City of Sandpoint. Easement to be aquired and permr pulled. Temp hook up ok.
	05/19/2015 05/19/2015		COMPLIANCE	(5/20/2015 8:28 AM MBO) Rocky Kennedy at 142 4 Mile,Coolin
	04/06/2015 04/06/2015		COMPLIANCE	(4/7/2015 7:58 AM MBO) CHECK JOE GISH 018423 AT 477100 HWY 95
	06/29/2015 06/29/2015		COMPLIANCE	(6/30/2015 7:34 AM MBO) Nathan Anderson/ lwr pack river rd
	06/30/2015 06/30/2015		COMPLIANCE	(7/1/2015 7:53 AM MBO) CHECK STEPHAN GREEN ,APPRENTICE AND THOMAS PARKER AT304 HORTON CRK,PL
	06/25/2015 06/25/2015		COMPLIANCE	(6/29/2015 7:33 AM MBO) ZACHARY ELSBERRY AT506 ANTONE

MARK WENIG **4**

<u>Permit No</u>	<u>Scheduled Date Completed Date</u>	<u>Remarks</u>	<u>Result</u>	<u>Notes</u>
VER1501-00035	05/19/2015	SCENIC BAY MARINA	COMPLIANCE	(5/20/2015 7:41 AM MWEN)
	05/19/2015	MEETING AT CDA OFFICE		MET GARY SONNEN, MICK RADY, AND JOHN MERIDITH AT DOCK E OF SCENIC BAY MARINA, TO GO OVER WHO DID THE NO COMPLIANT WIRING

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00035	05/06/2015	MEETING CDA OFFICE	ADMIN TIME	(5/7/2015 7:20 AM MWEN)
	05/06/2015			MEETING AT CDA OFFICE
		MEETING AT CDA OFFICE		
	06/10/2015	PERSI RETIREMENT SEMINAR	ADMIN TIME	(6/11/2015 7:45 AM MWEN)
	06/10/2015			PERSI RETIREMENT SEMINAR AT TRIPLE PLAY 3.5 HOURS
	04/29/2015	CODE UPDATE CLASS	ADMIN TIME	(4/30/2015 7:50 AM MWEN)
	04/29/2015			MEETING AT CDA OFFICE UNTILL 12:00PM

MITCH DAY **7**

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00040	04/13/2015		COMPLIANCE	(4/15/2015 1:59 PM MDA)
	04/13/2015			checked licenses 009743 and 022373 while inspecting web1504-00036 which were ok , but found concrete contractor had installed conduit issued enforcement permit ele1504-00215 and NOV case # ele1504-0059.
	04/15/2015		COMPLIANCE	(4/15/2015 1:53 PM MDA)
	04/15/2015			checked licenses 017982, 000617 while inspecting web1504-00192
	04/23/2015		COMPLIANCE	(4/23/2015 9:16 AM MDA)
	04/23/2015			checked licenses roy jolley appr 022715 and appr chad clark 022714 while inspecting web1504-00036. 2 jrn checked earlier on job jeremiah and lucus
	05/27/2015		COMPLIANCE	(5/28/2015 8:10 AM MDA)
05/27/2015			checked license 022965-A on web1409-00690	
	05/21/2015		COMPLIANCE	(5/26/2015 8:25 AM MDA)
	05/21/2015			checked licenses 022820 A & 022904 A. on job web1409-00690.
	05/11/2015		COMPLIANCE	(5/12/2015 8:32 AM MDA)
	05/11/2015			checked licenses on job web1409-00690.shelley jerky plant. 018780 A 012041 A 012042 A ele-j-28591 015200 A 018243 A 010450 J 001954 M 012707 J

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00040 06/16/2015
06/16/2015

ADMIN TIME

(6/17/2015 7:59 AM MDA)
completed harasment training.

RICK DOYLE **3**

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00043	04/16/2015		COMPLIANCE	(4/17/2015 1:49 PM RDO)
	04/16/2015			4/16/2015 RD.I went by the site of (2) new pivots being installed in seperate areas in the Salmon area to see if and electrical work had been started on either.I have information that a non licensed person plans to wire the pivots.No wiring has been done at either location at this time.I will continue to keep an eye on these installations.
	04/14/2015		ADMIN TIME	(4/14/2015 5:11 PM RDO)
	04/14/2015			4/14/2015 RD.I attended a one hour presentation in Salmon that was presented by Persi which explained the new changes to Persi effective 4/30/2015.
	04/29/2015		ADMIN TIME	(5/2/2015 10:45 AM RDO)
	04/29/2015			4/29/2015 RD.I drove to DBS Pocatello to attend a electrical inspector meeting.

RICK YOUNG **23**

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00044	04/02/2015		ADMIN TIME	(4/2/2015 8:19 PM RYO)
	04/02/2015			meeting with fellow inspectors and Jerome city building inspector
	06/01/2015		ADMIN TIME	(6/4/2015 6:26 PM RYO)
	06/01/2015			meeting with former Supervisor and retired inspector
	06/11/2015		ADMIN TIME	(6/11/2015 10:03 PM RYO)
	06/11/2015			4 hour class at csi with Mike Hyde and John Nielsen
	06/09/2015		ADMIN TIME	(6/9/2015 7:18 PM RYO)
	06/09/2015			Met with excavator to discuss installation of grease trap for restraunt
	06/09/2015		ADMIN TIME	(6/9/2015 7:17 PM RYO)
	06/09/2015			oil change at Jiffy lube

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00044	06/04/2015		ADMIN TIME	(6/4/2015 6:27 PM RYO)
	06/04/2015			Meeting with Jerome Bldg. inspector and county commissioner
	06/03/2015	208-539-9636	ADMIN TIME	(6/3/2015 10:01 PM RYO)
	06/03/2015			unlawful harassment prevention certification
	06/11/2015		ADMIN TIME	(6/11/2015 10:05 PM RYO)
	06/11/2015			worked on fee due issue for a commercial job involving Elvirea and Idaho sand and gravel
	04/13/2015		ADMIN TIME	(4/13/2015 6:23 PM RYO)
	04/13/2015			meeting with supervisors and other inspectors
	04/01/2015		ADMIN TIME	(4/1/2015 6:57 PM RYO)
	04/01/2015			covered for GJ while he covered for JG who was on vacation.
	04/02/2015		ADMIN TIME	(4/2/2015 8:20 PM RYO)
	04/02/2015			Covered for GJ while he covered for JG who was on vacation
	06/17/2015		ADMIN TIME	(6/17/2015 8:18 PM RYO)
	06/17/2015			Worked with elvira on a fee due for a commercial job
	06/18/2015		ADMIN TIME	(6/18/2015 7:50 PM RYO)
	06/18/2015			met with former supervisor and Jerome City bldg. insp.
	06/18/2015		ADMIN TIME	(6/18/2015 7:51 PM RYO)
	06/18/2015			Researched a failure to permit complaint by Mark Allen excavation which turned out to be a health dept permit not DBS
	06/22/2015		ADMIN TIME	(6/22/2015 6:59 PM RYO)
	06/22/2015			meeting with former supervisor
	06/22/2015		ADMIN TIME	(6/22/2015 7:01 PM RYO)
	06/22/2015			Dealt with multiple phone call concerning a sewer line in Wendell with no permit or inspection
	06/25/2015		ADMIN TIME	(6/25/2015 8:24 PM RYO)
	06/25/2015			Meeting with Jerome City Bldg. insp. and other inspectors
	04/07/2015		ADMIN TIME	(4/7/2015 6:25 PM RYO)
	04/07/2015			met with job superintendant and plumber on new jerome county jail project
	04/06/2015		ADMIN TIME	(4/6/2015 6:57 PM RYO)
	04/06/2015			meeting with current supervisor and other area 2b inspector

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00044	06/15/2015	ADMIN TIME	(6/15/2015 6:34 PM RYO)
	06/15/2015		worked with Nesa excavation to resolve sewer issues on 220' line
	06/15/2015	ADMIN TIME	(6/15/2015 6:33 PM RYO)
	06/15/2015		meeting with former supervisor
	04/22/2015	COMPLIANCE	(4/22/2015 9:45 PM RYO)
	04/22/2015		Curtis R Miller 020479 exp 8-31-19
			Brad Hewitt unlicensed told to stop work forman and job super informed.
			lynn Schwab 022133
	04/06/2015	COMPLIANCE	(4/6/2015 7:00 PM RYO)
	04/06/2015		Gabriel Acuna 013595 exp 8/31/17
			Michael Legg J-16432 exp 4/30/15
			Kolten Ellsbury 020712 exp 8/31/19

ROB BAFUS **1**

<u>Permit No</u>	<u>Scheduled Date Completed Date</u>	<u>Remarks</u>	<u>Result</u>	<u>Notes</u>
VER1501-00045	06/30/2015 06/30/2015		ADMIN TIME	(7/1/2015 8:36 AM RBA) Attended retirement party for Jeri Groth

ROBERT CRISPIN **53**

<u>Permit No</u>	<u>Scheduled Date Completed Date</u>	<u>Remarks</u>	<u>Result</u>	<u>Notes</u>
VER1501-00046	04/24/2015		ADMIN TIME	(5/7/2015 9:48 AM RCRI)
	04/24/2015			1- Schedule plumbing inspections 2- Verifications 3- I-Time
	04/01/2015		ADMIN TIME	(4/6/2015 8:06 AM RCRI)
	04/01/2015			1- Jury duty lemhi county

7/9/2015

10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00046	06/02/2015	ADMIN TIME	(6/5/2015 9:28 AM RCRI)
	06/02/2015		1- talked and emailed Mike Davis regarding Ken Babbcock homeowner plumbing extension. information regarding NOV for Joey Yazzie, empolyee of Conan heating and airconditioning
	04/20/2015	ADMIN TIME	2- scheduled inspections (4/24/2015 10:11 AM RCRI)
	04/20/2015		1- Industrial safety indpections with Jeff Harris, Salmon school dist. office, pioneer school, bus shop, maintenance bldg.
			2- JT, summers plbg. questions regarding mixing valves on tubs.
	04/10/2015	ADMIN TIME	3- Ken Schreckengost(homeowner) questions regarding permitting and inspections. (4/17/2015 11:17 AM RCRI)
	04/10/2015		1- review of the Idaho general health and safety standards for upcoming industrial safety inspections.
	04/07/2015	ADMIN TIME	(4/9/2015 11:50 AM RCRI)
	04/07/2015		1- scheduled inspections 2- contacted by home owner John Peva with question regarding plumbing and plumbing permits. 3- contacted by homeowner Randy with plumbing and plumbing permit questions.
	04/06/2015	ADMIN TIME	(4/9/2015 11:47 AM RCRI)
04/06/2015		1- contacted by Chris Jensen and informed that an inspection is required on the Salmon middle school Annex building for the Carmen Charter School refered by Kelly Pierce. I contacted Jim Smith superintendent of salmon school dist. and scheduled an inspection for thursday the 9th at 9 am. (4/24/2015 10:24 AM RCRI)	
04/22/2015	ADMIN TIME	1- Industrial safety inspections with Jeff Harris, Leadore and Tendoy schools	
04/22/2015			
06/04/2015	ADMIN TIME	2- scheduled inspections (6/15/2015 2:07 PM RCRI)	
06/04/2015		schedule inspections, Howe idaho, arco and mackay	
04/23/2015	ADMIN TIME	(4/24/2015 10:30 AM RCRI)	
04/23/2015		1- scheduled inspections	
		2- follow up investigation Handyman Jeremiah Johnston MacKay ID. 208-313-1853, stopped at Amy Lous cafe in Mackay discovered advertisement for plumbing and electrical work with Jeremiahs name and phone number, took picture with phone of sign. was not able to find out address through google or other means of internet. contacted Adam Bowcutt for help. (4/6/2015 8:07 AM RCRI)	
04/02/2015	ADMIN TIME	1- Jury Duty, Lemhi county	
04/02/2015			

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00046	04/27/2015	ADMIN TIME	(5/7/2015 9:52 AM RCRI)
	04/27/2015		1- Industrial safety inspections with Jeff Harris, University of Idaho Ranch
	04/17/2015	ADMIN TIME	(4/24/2015 10:04 AM RCRI)
	04/17/2015		1- Athan Harrigfeld sewer and water inspection
			2- investigate Jeremiah, Handyman in MacKay advertising plumbing and electrical services.
			3- Mike Moulton Rays plbg. questions regarding plumbing requirements for remodel of saweway store.
			4- computer assistance from Chris Heaner for industrial safety inspections
	06/26/2015	ADMIN TIME	(6/30/2015 3:41 PM RCRI)
	06/26/2015		1- Contacted Salmon Bldg. Dept. inquired information On Grant Coxs building permit for garage construction with plbg., Mr. Cox pulled a Building permit August 6th 2014, verified there would be no plumbing by marking the "NO" box on his permit application.
			2- went to visit Mr. Cox at Elk Bend location, Mr. Cox was not present nor any venicles so I did not stop.
06/03/2015	ADMIN TIME	(6/5/2015 9:33 AM RCRI)	
06/03/2015		1- Bruce Sequeiros- J&R plumbing information on scheduling inspection for plumbing ground work in MacKay.	
		2- Wrote NOV on Joey Yazzie non-licensed employee of Conan Heating, Arco clinic remodel job.	
06/16/2015	ADMIN TIME	(6/18/2015 10:51 AM RCRI)	
06/16/2015		1- contacted by Salmon school superintendent Chris Born regarding finding an engineer to design the replacement of the water piping in the pioneer school facility.	
		2- Dave Lewis homeowner plumbing inspection, owner was not ready and did not understand the inspection process.	
		3- contacted by homeowner NickSequarious, questions regarding water main installations.	
04/13/2015	ADMIN TIME	(4/24/2015 9:35 AM RCRI)	
04/13/2015		1- Industrial safety inspections with Jeff Harris in Stanley, Challis elementary and middle school.	
		2- Randy Chote(homeowner) questions regarding permitting and inspection requirements.	
04/08/2015	ADMIN TIME	(4/9/2015 11:57 AM RCRI)	
04/08/2015		1- scheduled industrial safety inspections with Jeff Harris at the MacKay high school and MacKay elementary/ junior high school and all surrounding buildings.	
		2- plumbing roughin inspection East Fork Salmon river for Halls Plumbing	

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00046	06/30/2015 06/30/2015	ADMIN TIME	(6/30/2015 3:51 PM RCRI) 1- Industrial Safety inspections at the Pahsimeroi Fish and Game Hatcherys, upper and lower. 2- Custer co. permit compliance check, drove around Challis community. 3- Verification reports 4- Scheduled tire replacement with Les Schwab in Salmon for car drop off Thursday 2nd, pick-up Monday July 6th. (4/9/2015 11:40 AM RCRI) 1- performed schedule inspections 2- contacted by Jeff Harris fro industrial safety inspection schedule for the month of april, informed I need the Excel program for resulting industrial inspections. Contacted Chris Heaner with IT and installed the program on my desktop. (6/30/2015 3:33 PM RCRI) 1- Scheduled inspections Butte and Custer county 2- received spare car from Adam and took him to Arco with me to meet Chris so Adam could ride back to Idaho Falls. Now driving Adams car. 3- Permit compliance check Lot 15 & 16 Agate rd. Elk Bend, owner Grant Cox. Discovered owner installed plumbing in garage, plumbing fixtures include Shower, Toilet, Laundry sink, Washer and water heater. No permit was pulled, no plumbing inspection performed, construction is finished. Contacted Brandee in main office and issued an inforcement permit, will write an NOV and NOC after gaining more information. (4/17/2015 11:15 AM RCRI) 1- performed building inspection at the Salmon middle school annex with superintendent Jim Smith, reported back to Chris Jensen with findings. 2- scheduled inspections (6/30/2015 3:12 PM RCRI) 1- scheduled inspections Plbg. & HVAC 2- Gene Westergard, excavtor contractor permit and inspection questions. 3- Doug Dishaman, owner of KOA campground in Arco, Inforcement Permit, NOV & NOC, installed grease hood, exhaust and ducting in small cafe building. Wrote inforcement with Mike Davis.
	04/03/2015 04/03/2015	ADMIN TIME	
	06/24/2015 06/24/2015	ADMIN TIME	
	04/09/2015 04/09/2015	ADMIN TIME	
	06/18/2015 06/18/2015	ADMIN TIME	

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00046	04/16/2015	ADMIN TIME	(4/24/2015 9:56 AM RCRI)
	04/16/2015		1- performed mod hook-up inspection for Rays plbg, diccovered no permit was pulled for sewer and water mains to mod, installed by homeowner Athan Harrigfeld. Contacted Athan and informed him of State requirements, Athan pulled a permit and scheduled an inspection for friday the 17th
	04/14/2015	ADMIN TIME	2- scheduled inspections
	04/14/2015		(4/24/2015 9:38 AM RCRI)
	06/22/2015	ADMIN TIME	1- Industrial safety inspections with Jeff Harris Challis high school and surrounding facilities.
	06/22/2015		(6/30/2015 3:13 PM RCRI)
	04/21/2015	ADMIN TIME	1- Took vacation time for personal leave.
	04/21/2015		(4/24/2015 10:16 AM RCRI)
	05/05/2015	ADMIN TIME	1- Industrial safety inspections with Jeff Harris,Salmon high school and adjacent facilities, Carmen Charter School.
	05/05/2015		2- Scheduled inspections.
		(5/14/2015 2:24 PM RCRI)	
		1- contacted Rick Doyle asked hi to follow up a permit compliance at Williams lake Salmon, was contacted by Salmon bldg. dept. about possible violations. Rick informed me of a house in Arco (Sunset drive) that needs checked for a plumbing permit.	
		2- investigated Williams lake job. discovered Mickey Hendricks was repairing broken water lines at the house due from last winter freezing. 36 Bayview dr.	
		3- Computer help with Chris at IT with industrial safety inspection emails.	
05/21/2015	ADMIN TIME	(6/5/2015 9:12 AM RCRI)	
05/21/2015		1- schedule inspections plumbing.	
06/15/2015	ADMIN TIME	(6/18/2015 10:45 AM RCRI)	
06/15/2015		1- Industrial safety reports East Fork Salmon fish Hatchery.	
		2- Emailed safety reports to Yankee Fork Parks and Recreation	
		3- meet with Rick from Salmon river propane and went through unit heater installation requirements in Salmon school bus shop.	
		4- contacted Todd Garlie, Pahsimeroi fish hatchery and Paul Abbot, Idaho Power and scheduled safety inspection at Pahsimeroi fish hatchery.	

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00046	06/12/2015	ADMIN TIME	(6/18/2015 10:37 AM RCRI)
	06/12/2015		1- Industrial safety inspection results for Idaho Parks and recreation, Yankee fork facility.
			2- contacted by local plumbing contractor regarding information pertaining to unlicensed person performing plumbing work for other individuals. Name of person not known, location of site 14 miles south hwy 93.
	06/10/2015	ADMIN TIME	(6/15/2015 2:15 PM RCRI)
	06/10/2015		1- license check Robinson electric Challis Id. employees working at 999 Garden creek rd. Chakkis. Keith Sunday Jr. Lic.# ELE Apprentice 022925
			Chunck Wunsch Lic# ELE. Master 018466
			Ethan Robinson Lic# ELE Apprentice 011061
	06/29/2015	ADMIN TIME	2- Scheduled inspections (6/30/2015 3:48 PM RCRI)
	06/29/2015		1- Scheduled inspections
			2- drove to Idaho Falls to pick up Adam so we could switch out cars, mine is ready for pick up at quality motors.
05/08/2015	ADMIN TIME	3- washed car at local car wash \$8.00 cash. (5/14/2015 2:31 PM RCRI)	
05/08/2015		1- Sick leave	
05/11/2015	ADMIN TIME	(5/14/2015 2:34 PM RCRI)	
05/11/2015		1- Scheduled inspections	
06/01/2015	ADMIN TIME	2- Salmon Fish & Game safety reports (6/5/2015 9:22 AM RCRI)	
06/01/2015		1- Industrial safety inspection with Russ and Adam at U of I Geology compound.	
05/29/2015	ADMIN TIME	2- plumbing inspection High country plbg. (6/5/2015 9:17 AM RCRI)	
05/29/2015		1- scheduled inspections	
		2- Industrial safety inspection information regarding U of I geology compound in Chilly Id. Will meet with Adam and Russ at complex on Monday the 1st. (6/5/2015 9:13 AM RCRI)	
05/22/2015	ADMIN TIME	1- scheduled inspections.	
05/22/2015			

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00046	04/15/2015	ADMIN TIME	(4/24/2015 9:43 AM RCRI)
	04/15/2015		1- Industrial safety inspections with Jeff Harris, Challis BLM recreation center, Arco dist. 6 health office.
	05/14/2015	ADMIN TIME	2- Randy Chote grd. work inspection (5/19/2015 10:14 AM RCRI)
	05/14/2015		1- contacted by Jeff Harris, Jeff asked me to look into two buildings that might need a safety inspection due to the possibility of being occupied. East Idaho tech. college on Monroe street in Salmon no longer use the building space. Building #2 Office of Species conservation, not yet determined if used.
	04/28/2015	ADMIN TIME	2- Contacted by Wayne Smith with U of I Ranch in Salmon asking how to respond to safety report. (5/7/2015 9:57 AM RCRI)
	04/28/2015		1- Industrial safety inspections with Jeff Harris, District seven health, Liquior store, Labor department and vocational rehab 2- Computer help with Eric from IT, installing H-drive for resulting safety inspections. 3- scheduled inspections plumbing.
	06/17/2015	ADMIN TIME	(6/18/2015 11:02 AM RCRI)
	06/17/2015		1- scheduled inspections Butte and Custer counties. 2- compliance verification KOA campground Arco, Idaho. Drove by facility and discovered commercial grease exhaust mounted on small out building advertising food. approached facility and discovered kitchen grease hood installed by owner Doug Dishaman, 2424 w. 3000 County rd., Arco, Idaho. Hood and grease duct installed incorrectly, no permit pulled or inspections performed. I informed Doug of the requirements concerning commercial HVAC installations and informed him I would issue an Inforcement permit write a notice of violation with a correction notice. Informed Doug of his options of contacting a licensed contractor or removing the appliances.
	06/23/2015	ADMIN TIME	(6/30/2015 3:22 PM RCRI)
	06/23/2015		1- vehicle repairs, exhaust manifold cracked. dropped off at Quality motors on Salmon, estimated time for repairs one week. Scheduled time to get a vehicle from Adam Bowcutt.
05/20/2015	ADMIN TIME	2- Industrial safety inspection review for Pahsimeroi Fish And Game Hatcherys (6/5/2015 9:10 AM RCRI)	
05/20/2015		1- Information on grease hood and ducting for U of I kitchen hood installation. 2- contacted by Kevin Butler(homeowner) wanting information on inspections for plumbing new construction. 3- contacted by Dale Bates wanting information regarding rerquirements on Hood installation at U of I compound in Chilly, Id	

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00046	04/29/2015	ADMIN TIME	(5/7/2015 10:07 AM RCRI)
	04/29/2015		1- scheduled inspections
			2- peerforming Plumbing inspections at Arco Medical Clinic Remodel, discovered an employee Joey Yazzie for Conan Heating that is not signed up with the state as an apprentice. Joey was standing on a ladder installing duct work for the termination point. Contacted Brent Conan owner of Conan Heating and informed him of the violation.
	04/30/2015	ADMIN TIME	(5/7/2015 10:12 AM RCRI)
	04/30/2015		1- Contacted by Terry(Tros Plbg) information on Handicap bathrooms
			2- Wrote notice of violation to Conan Heating
			3- filled industrial safety inspection reports
	05/01/2015	ADMIN TIME	(5/7/2015 10:16 AM RCRI)
	05/01/2015		1- scheduled inspections
			2- attempted to email industrial safety inspections failed to download from H-drive.
05/07/2015	ADMIN TIME	(5/14/2015 2:30 PM RCRI)	
05/07/2015		1- Shane Hilton plumbing scheduled an inspection discovered contractor who installed sewer main had not pulled a permit for work done. Contacted Allen Probst of Salmon informed hi of the state requirements. Allen informed me he would pull a permit and schedule an inspection, that he was unaware of the process.	
		2- Scheduled inspections.	
05/12/2015	ADMIN TIME	(5/19/2015 10:07 AM RCRI)	
05/12/2015		1- scheduled inspections	
		2- industrial safety reports, Fish and game office in salmon.	
05/19/2015	ADMIN TIME	(6/5/2015 9:06 AM RCRI)	
05/19/2015		1- scheduled inspections	
		2- Theresa with Lemhio co. bldg. dept. contacted me with info regarding possible noncompliance in challis.	
		3- Industrial Safety inspection emails.	
		3- contacted Darren McRay with questions regarding kitchen hood in Chilly Idaho at U of I compound.	
		4- Emailed John Nelsen for information regarding U of I kitchen hood in Chilly, ID. wanted to know if BS&R had submitted any design sheets for hood.	
05/15/2015	ADMIN TIME	(5/19/2015 10:19 AM RCRI)	
05/15/2015		1- contacted by Drake with BSR services inquiring information on inspection days for Custer Co.	
		BSR is installing a grease hood in Main kitchen at U of I compound in Chile Id.	
		2- review of IMC code book on grease hood and ducting.	
		3- review of Idaho general health and safety guidelines.	

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00046	05/18/2015	ADMIN TIME	(6/5/2015 8:58 AM RCRI)
	05/18/2015		1- industrial safety inspection Department of health and welfare, safety report
	05/04/2015	ADMIN TIME	2- HVAC review grease hood and ducting requirements. (5/7/2015 10:23 AM RCRI)
	05/04/2015		1- contacted By Jeff Harris went through facility list for Lemhi, Custer and Butte counties 2- contacted Chris Haener scheduled confrence to go through computer problems with H-Drive 3- Contacted by Theresa with Lemhi Building dept. verification on project up Williams Lake.

SAM KASPER **6**

Permit No	Scheduled Date Completed Date	Remarks	<u>Result</u>	Notes
VER1501-00047	05/07/2015		ADMIN TIME	(5/7/2015 8:51 PM SKA)
	05/07/2015			Attended lunch meeting with Mr. Jeffres in Moscow
	06/18/2015		ADMIN TIME	(6/18/2015 8:10 PM SKA)
	06/18/2015			Took Ford to dealer to determine cause of overheating, Turbo was overboosting engine beyond its specs. Radiator was clogged. Mechanic said vapor control system was defunct.
	04/09/2015		ADMIN TIME	(4/9/2015 7:48 PM SKA)
	04/09/2015			Attended Inspector meeting with Larry at Moscow
	04/08/2015		ADMIN TIME	(4/8/2015 7:33 PM SKA)
	04/08/2015			Ran to Lewiston to ensure delivery of DBS order and punch list to Lawyer James Grow concerning Orofino Creek Court.
	04/28/2015		ADMIN TIME	(4/29/2015 6:13 PM SKA)
	04/28/2015			Rob Bafus contacted two apprentices and called about them being without supervision. I visited the site and the apprentices (4th and 3rd year) were there along with the master for the company.(Sparky's Electric out of Clarkston Wa.) I iterated the need for supervision, but accepted his explanation that he was fetching parts, as he has consistently been on the job on previous visits.
	04/29/2015		ADMIN TIME	(5/1/2015 8:39 PM SKA)
	04/29/2015			Attended inspector meetingin Cour D Alene.

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

SHELLY FARRIS

2

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00048	04/24/2015		COMPLIANCE	<<SFA:1504270830590001>>
	04/24/2015			
	06/03/2015		ADMIN TIME	(6/4/2015 8:55 AM SFA)
	06/03/2015			3 hours spent down loading adobe flash player and then taking required sexual harassment training.

TIM DUCOMMUN

6

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00050	04/27/2015		ADMIN TIME	(4/27/2015 8:10 AM TDU)
	04/27/2015			Take off winter tires & install summer tread @ Les Schwab.
	06/30/2015	ver1501-0050	ADMIN TIME	(6/30/2015 6:46 PM TDU)
	06/30/2015			Jeri Groth Retirement party
	04/29/2015		ADMIN TIME	(4/28/2015 6:27 PM TDU)
	04/28/2015			Insp. meeting
	05/18/2015		ADMIN TIME	(5/18/2015 7:02 PM TDU)
	05/18/2015			Oil change and service D.B.S. 189 State subaru
	05/11/2015		ADMIN TIME	(5/11/2015 6:31 PM TDU)
	05/11/2015			(5/11/2015 6:33 PM TDU)
	05/07/2015		ADMIN TIME	Carding of Jason Taft J- 28096 and Mark Strom A-010634.
	05/07/2015			(5/7/2015 6:24 PM TDU)
	05/07/2015			Inspector Meeting with Larry @ Moscow

TIM GROVE

1

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
-----------	----------------------------------	---------	--------	-------

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00051 05/11/2015
05/11/2015

COMPLIANCE

New truck in town. Stopped and talked to Jeff Stiner.
Journeyman's license ok. To test for Contractors in next 2 weeks

TODD WILDING

17

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00052	06/30/2015 06/30/2015	see notes	ADMIN TIME	(7/1/2015 7:41 AM TWI) appointment with vehical to see why it is over heating on me. hunzacker ford in soda looked at it. cleaned the radiatorfull of bugs did not help still does it. appointment for tuesday july 7 to take it back.
	06/25/2015 06/25/2015	see notes	ADMIN TIME	(6/26/2015 7:44 AM TWI) stopped in and talked with bear river owner about the new policy on energizing panels
	05/08/2015 05/08/2015	see notes	COMPLIANCE	(5/8/2015 11:04 AM TWI) stopped and talked with JOsh JY elec. just started job in lava hot springs.
	05/19/2015 05/19/2015	see notes	PASS	(5/20/2015 7:34 AM TWI) recieved a call if i would stop by and take allok a his project and see if he was going in the right direction. he is changing out house panels and removing elec heat from load. he asked if the wire he bought was the right size yes, and if panel location was still ok. yes. and had ?'s about permitting.
	05/11/2015 05/11/2015	see notes	PASS W/CONDITIONS	(5/12/2015 7:24 AM TWI) stopped by permit WEB1505-00715 to look at the temp. no temp installed at this time
	06/25/2015 06/25/2015	see notes	ADMIN TIME	(6/26/2015 7:43 AM TWI) stopped by ford dealer in soda springs to scheduel appointment for car. appointment is for tuesday the 30th.
	04/29/2015 04/29/2015	see notes	ADMIN TIME	(4/30/2015 8:32 AM TWI) inspectors meeting in pocatello 4 hrs.
	06/01/2015 06/01/2015	see notes	COMPLIANCE	(6/2/2015 8:21 AM TWI) stopped by ParadICE shack (snow cones) left card so they can contact me, i got owners phone #, tried calling left message needing permit for setting up shack. waiting to hear back from owners Haily and Casey Judd(435)787-8395
	06/01/2015 06/01/2015	see notes	COMPLIANCE	(6/2/2015 7:59 AM TWI) stopped by permit WEB1504-02521 looking for people to check licenses on found the elec. working, not ready for rough inspection Rod Cornia, and jarmin greenlee working both good with their license.

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00052	06/18/2015	see notes	ADMIN TIME	(6/19/2015 7:47 AM TWI)
	06/18/2015			Bear Lake County inspector called earlier in the week needing some bussness cards told him i would bring him some. met him in Georgetown. talked about the area and what the outlook looked like. some building is come up.
	06/17/2015	see notes	ADMIN TIME	(6/18/2015 7:49 AM TWI)
	06/17/2015			stopped in on acouple of jobs to talk with elec. contractors about the new energize service policy. talked with S and T elec. and also Bowles Stateline, gave them a copy of the list of inspection first before energize.
	06/17/2015	see notes	COMPLIANCE	(6/18/2015 7:44 AM TWI)
	06/17/2015			checked lyle d geary's license m-022098
	06/10/2015	see notes	ADMIN TIME	(6/11/2015 7:46 AM TWI)
	06/10/2015			Pocatello office emailed me saying they needed some business cards so i ran some up. also stopped in to a supply house to ask question about the new combo CAFI/GFCI breakers from SQ.D they do meet the requirments for personel protection 6 miliamps.
06/29/2015	see notes	COMPLIANCE	(6/30/2015 7:40 AM TWI)	
06/29/2015			checked Daniel Boehme A-022318 ok	
04/24/2015	see notes	ADMIN TIME	(4/24/2015 7:42 AM TWI)	
04/24/2015			did a online solar class took about 3 1/2 hrs along with some office stuff called some contractors	
06/01/2015	see notes	ADMIN TIME	(6/2/2015 7:53 AM TWI)	
06/01/2015			spent time doing the harassment training online.	
05/11/2015	see notes	COMPLIANCE	(5/12/2015 7:21 AM TWI)	
05/11/2015			stopped by job stateline zan bowles is doing. talked with matt, and zan talked about jobs they have open and the job they are doing at that location.	

TRAVIS WRIGHT **18**

Permit No	Scheduled Date Completed Date	Remarks	Result	Notes
VER1501-00053	04/17/2015		PASS	(4/17/2015 1:12 PM TWR)
	04/17/2015			I drove around the Riverdale area looking for jobs that may be going on that I may not now about. I did not find any today.
	04/17/2015		COMPLIANCE	(4/17/2015 1:10 PM TWR)
	04/17/2015			I had carded a HVAC worker on the job site. Mitch Lish ELE-SJ-20213 Exp: 7-31-16 HVC-J-997 Exp: 2-28-16

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00053	06/10/2015	PASS	(6/11/2015 7:17 AM TWR)
	06/10/2015		Whent to pocatello to the CODE Update class. I started work at 6:00 am to be able to get there in time for the class that John Neilsen put on.
	05/05/2015	PASS	(5/5/2015 4:21 PM TWR)
	05/05/2015		I went to Pocatello and had the windshield replaced on the state car and got the fire extinguisher recertified.
	04/08/2015	COMPLIANCE	(4/8/2015 3:20 PM TWR)
	04/08/2015		I stoped at a home at 2061 S. 8th st. in Montpelier. owner's name is Randy Lancaster, Wife's nam is Mariah Lancaster. Phone 307-887-2855. They are building a new home and I explained to them that they have to have a PLB permit to be doing work on the home. They are suposidly pullying the permit tonigh. I will check for one in the morning and if not then I will ishew one at that point. I have been in contact with Adam Bowcut about this home so he is aware of all that is going on.
	04/27/2015	COMPLIANCE	(4/27/2015 2:30 PM TWR)
	04/27/2015		I had received an anonymous phone call that some one is doing plumbing work on a small commercial building with out a license. I stopped at the job site and the doors were lock. No one answered when I knocked. It looks like there is some construction going on inside but I don't now what is being done. I left a door knocker on the door stating if any PLB or electrical work is being done they need to call me. The job address is 833 Washington St. in Montpelier.
	06/15/2015	COMPLIANCE	I got the owners name and phone # of the building I am not shore on the correct spelling. Radick # 1-801-706-4004
	06/18/2015		I talked to the owner and from what he said they are just going to get started on the plumbing and they have not done anything yet with it. I explained that he will need to higher a licenced plumbing contractor to do the work. I will wate to here from him. (6/18/2015 4:14 PM TWR)
			I had carded some electricians on 6-15-15 and just forgot to put in the verification. Carter S Knudsen 019605 EXP. 6-30-19
	05/27/2015	COMPLIANCE	Shawn Carter ELE-j-26015 Exp. 12-31-17 C-010223 Exp. 10-31-15 (5/27/2015 2:56 PM TWR)
	05/27/2015		Had a plumber call and asked if I could stop by a comercial job they are looking at getting started on. They had some code question on what was alowed on a existing kitchen. this is for the school kitchen in Preston. contractor does not have a permit at this time but will get one in the next day or two. they have not started the job yet but need some answers to be able to give a proper bid.

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00053	04/20/2015	PASS	(4/20/2015 2:55 PM TWR)
	04/20/2015		I went and did my inspection with to a while to get there because I drove around a little to look for other jobs that may be going. Had to go over the job with the home owner. he was running late so I waited there for just a bit till he got there.
	06/10/2015	COMPLIANCE	(6/11/2015 7:21 AM TWR)
	06/10/2015		Carded some HCAC guys. Douglas Bair HVAC-j-4787 Exp.5-31-18 HVAC-c-10162 Exp. 5-31-17
	06/01/2015	PASS	Bryce L Bair Apprentice 012401 Exp. 4-30-17 (6/1/2015 12:15 PM TWR)
	06/01/2015		I took the harassment prevention/Respectful workplace Training today. Answered several code questions for people. So with that I studied code for a few hours today, and I am going to take some time to cleanup the state car.
	04/24/2015	COMPLIANCE	(4/24/2015 7:11 AM TWR)
	04/24/2015		I did an inspection on a commercial job for the HVAC and carded the two guys that were there.
			Jason Weeks HVC-J-10110 Exp. 1-31-17
			Edger Gonzalez Apprentice 008809 Exp. 1-31-16
	05/20/2015	PASS	They are both current (5/20/2015 3:06 PM TWR)
	05/20/2015		I did my inspections and then read in the IRC code book for a few hours to answer some code questions for people.
	05/07/2015	COMPLIANCE	(5/7/2015 4:11 PM TWR)
	05/07/2015		I stopped by this job at 7936 Rex Dr. in Lava. They have not started any plumbing yet at this time.
	06/22/2015	PASS	(6/22/2015 1:37 PM TWR)
06/22/2015		I am taking the state car in to get tires rotated and oil change done.	
06/18/2015	COMPLIANCE	(6/18/2015 4:17 PM TWR)	
06/18/2015		I checked some PLB licenses.	
		The owner and Journeyman is Ral Services. he said he just lost his walet a couple of days ago so he needs to call and get a new license coming.	
		the Apprentice is Brendan Bartschi 022109 Exp. 2-28-20 (4/15/2015 2:53 PM TWR)	
04/15/2015	PASS	I studied in the code books for a good part of the day and answered code questions for those that called. Made phone calls to schedule times for jobs tomorrow. checked for jobs without inspections.	
04/15/2015			

7/9/2015
10:30:29AM

State of Idaho
"Verification" Inspections by Inspector
For the Period 4/1/2015 thru 6/30/2015

VER1501-00053 05/18/2015
 05/18/2015

PASS

(5/18/2015 1:51 PM TWR)
I maid some phone calls on some jobs that have not had inspection yet. Then I whent and looked for jobs I may not now about on the east side of bear lake and the west side. I hadnt had time to go look around in that area in a whil. so I did not find any construction going on that I did not already now about.

WARREN WING

1

<u>Permit No</u>	<u>Scheduled Date Completed Date</u>	<u>Remarks</u>	<u>Result</u>	<u>Notes</u>
VER1501-00054	02/02/2015 06/01/2015	License Verification	PASS	(2/3/2015 7:04 AM WWI) Checked license on following individuals on Mistyglen street in Boise. No site address available. James K. Sykes 33713 Expired in 2008, He left jobsite immediately and obtained his license. Michael Hruby ELE-A-29046 expires on 2-28-17 David Jackson ELE-J-22905 expires on 7-31-17 Mike Thompson 006327 expires on 6-30-16 Justin Elliot Expires 017907 expires on 2-28-19 Jose E Barajas 010416 expires on 12-31-16