


DIVISION OF BUILDING SAFETY

IDAHO HEATING, VENTILATION AND
AIR CONDITIONING BOARD
SPECIAL MEETING

OCTOBER 14, 2020



TENTATIVE AGENDA

NOTICE OF PUBLIC MEETING

**IDAHO HEATING, VENTILATION AND
AIR CONDITIONING BOARD SPECIAL MEETING**

**Division of Building Safety
1090 East Watertower Street, Suite 150, Meridian
1250 Ironwood Drive, Suite 220, Coeur d'Alene
155 North Maple Street, Blackfoot**

**Teleconference – 877-820-7831--529619
dbs.idaho.gov – (208) 332-7137**

Wednesday, October 14, 2020

**11:00 a.m.–11:30 a.m. (MDT)
10:00 a.m.–10:30 a.m. (PDT)**

**MASKS ARE REQUIRED FOR BOARD ROOM ATTENDANCE OR
TELECONFERENCING IS AVAILABLE AT THE NUMBER REFERENCED ABOVE**

11:00 a.m. CALL TO ORDER – Ted Sermon, Chairman
o Roll Call & Introductions

ACTION AGENDA

1. Vote to Authorize Notice of Omnibus Fee Rulemaking – Adoption of Pending Fee Rule with regard to IDAPA 24.39.70 in Docket Number 24-0000-2000F – Patrick J. Grace, Deputy Administrator

11:30 a.m. ADJOURN

All times, other than beginning, are approximate and scheduled according to Mountain Daylight Time (MDT), unless otherwise noted. Agenda items may shift depending on the Idaho Heating Ventilation and Air Conditioning Board's preference. 10/13/2020rb

IDAHO HEATING, VENTILATION AND AIR CONDITIONING BOARD

Agenda Item No. 01

Adoption of Pending Rules

PRESENTER: Patrick J. Grace, Deputy Administrator

OBJECTIVE: Approve the reauthorized HVAC Rules – IDAPA 24.39.70

ACTION: Vote to approve and authorize the reauthorized omnibus rules.

BACKGROUND: Administrative rule chapters that contain a fee in them were not reauthorized by the Idaho legislature in the 2020 legislative session. However, the Governor’s office had all executive agencies and boards promulgate temporary rules for such fee rule chapters several months ago so that they would still be in effect until the legislature can take up the matter again next session. The HVAC board rules were promulgated as temporary and proposed, and notices of such were published in special editions of the April 2020 and September 2020 administrative bulletins. The board previously approved such action at meetings earlier this year. As part of the rulemaking process, the rules were published in the September bulletin as “proposed” rules and opportunity was provided to the public to provide comment and submit views or arguments about the rules – after which time the rules enter into a “pending” state. No comment has been received by the Division about the HVAC rules to date. The final step in the board’s rulemaking approval process is to authorize the rules as pending for final submission to the legislature for review in the next legislative session.

ATTACHMENTS: Proposed HVAC rules; notice of omnibus rulemaking – proposed fee rule



**IDAPA 24 – DIVISION OF OCCUPATIONAL AND PROFESSIONAL LICENSES
DIVISION OF BUILDING SAFETY AND ITS CONSTITUENCY BOARDS**

DOCKET NO. 24-3900-2000F (FEE RULE)

NOTICE OF OMNIBUS RULEMAKING – PROPOSED RULE

AUTHORITY: In compliance with Sections 67-5221(1), Idaho Code, notice is hereby given that this agency has initiated proposed rulemaking procedures. The action is authorized pursuant to the following sections of Idaho Code:

I.C. § 39-4112	I.C. § 39-4113	I.C. § 39-4303	I.C. § 39-8605
I.C. § 44-2103	I.C. § 44-2107	I.C. § 54-1005	I.C. § 54-1006
I.C. § 54-1907	I.C. § 54-2605	I.C. § 54-2606	I.C. § 54-2607
I.C. § 54-4510	I.C. § 54-5017	I.C. § 54-5022	I.C. § 55-2203
I.C. § 55-2211	I.C. § 67-2601A		

PUBLIC HEARING SCHEDULE: Opportunity for presentation of oral comments concerning this rulemaking will be scheduled in accordance with Section 67-5222, Idaho Code.

DESCRIPTIVE SUMMARY: The following is the required finding and concise statement of the purpose of the proposed rulemaking:

This proposed rulemaking re-publishes the following existing temporary rule chapters previously submitted to and reviewed by the Idaho Legislature under IDAPA 07, Title 01, Chapter 01; Title 02, Chapter 02; Title 03, Chapters 01, 03, 11-12; Title 04, Chapter 02; Title 05, Chapter 01; Title 07, Chapter 01; Title 10, Chapter 01, now indexed as IDAPA 24, Title 39, Chapter 10; Chapter 20; Chapters 30, 31, 33, 34; Chapter 40; Chapter 50; Chapter 70; and Chapter 90, rules of the Division of Building Safety:

IDAPA 24.39

- 24.39.10, *Rules of the Idaho Electrical Board;*
- 24.39.20, *Rules Governing Plumbing;*
- 24.39.30, *Rules of Building Safety (Building Code Rules);*
- 24.39.31, *Rules for Modular Buildings;*
- 24.39.33, *Rules Governing Manufactured/Mobile Home Industry Licensing;*
- 24.39.34, *Rules Governing Manufactured or Mobile Home Installations;*
- 24.39.40, *Safety Rules for Elevators, Escalators, and Moving Walks;*
- 24.39.50, *Rules of the Public Works Contractors License Board;*
- 24.39.70, *Rules Governing Installation of Heating, Ventilation, and Air Conditioning Systems;* and
- 24.39.90, *Rules Governing the Damage Prevention Board.*

FEE SUMMARY: This rulemaking does not impose a fee or charge, or increase a fee or charge, beyond what was previously submitted to and reviewed by the Idaho Legislature in the prior rules. This rulemaking does not impose a fee or charge, or increase a fee or charge, beyond what was previously approved and codified in the prior rules. All fees contained in rule chapters covered by this notice relate to licensing and related administrative fees, fees to purchase permits or for the performance of inspections on various types of construction installations, or the assessment of civil penalties for non-compliance with applicable statutes.

The fees or charges are authorized in the following sections of Idaho Code:

I.C. § 39-4112	I.C. § 39-4113	I.C. § 39-4303	I.C. § 39-8605
I.C. § 39-8616	I.C. § 44-2103	I.C. § 54-1005	I.C. § 54-1014
I.C. § 54-2614	I.C. § 54-2616	I.C. § 54-1904	I.C. § 54-4510
I.C. § 54-5012	I.C. § 54-5017	I.C. § 55-2203	I.C. § 67-2601A

The following is a specific description of the fees or charges:

The preceding sections of Idaho Code and the attached rules provide a specific description of the fee or charge imposed by this rulemaking. This rulemaking does not impose a fee or charge, or increase a fee or charge, beyond what was previously approved and codified in the prior rules. All fees contained in rules covered by this notice relate to licensing and related administrative fees, fees to perform inspections on various types of construction installations, or the assessment of civil penalties for non-compliance with applicable statutes. All Division programs that are covered by this notice operate from statutorily created dedicated funds that provide for the licensing of persons within the respective professions, as well as the inspection of such installations and/or administration of such programs by the Division. All of these operations require the collection of certain fees to ensure compliance with applicable standards and to protect the health and safety of the public.

FISCAL IMPACT: The following is a specific description, if applicable, of any negative fiscal impact on the state general fund greater than ten thousand dollars (\$10,000) during the fiscal year: This rulemaking is not anticipated to have any fiscal impact on the state general fund because the FY2021 budget has already been set by the Legislature, and approved by the Governor, anticipating the existence of the rules and fees being reauthorized by this rulemaking.

NEGOTIATED RULEMAKING: Pursuant to Section 67-5220(2), Idaho Code, negotiated rulemaking was not feasible because engaging in negotiated rulemaking for all previously existing rules will inhibit the agency from carrying out its ability to serve the citizens of Idaho and to protect their health, safety, and welfare.

INCORPORATION BY REFERENCE: Pursuant to Section 67-5229(2)(a), Idaho Code, incorporated material may be obtained or electronically accessed as provided in the text of the proposed rules attached hereto.

ASSISTANCE ON TECHNICAL QUESTIONS, SUBMISSION OF WRITTEN COMMENTS: For assistance on technical questions concerning the proposed rule, contact MiChell Bird at (208) 334-3285.

Anyone may submit written comments regarding the proposed rulemaking. All written comments must be directed to the undersigned and must be delivered within twenty-one (21) days after publication of this Notice in the Idaho Administrative Bulletin. Oral presentation of comments may be requested pursuant to Section 67-5222(2), Idaho Code, and must be delivered to the undersigned within fourteen (14) days of the date of publication of this Notice in the Idaho Administrative Bulletin.

Dated this 19th day of August, 2020.

Idaho Division of Occupational and Professional Licenses
700 West State Street
Boise, ID 83702
PO Box 83720
Boise, ID 83720-0063
(208) 334-3233

**24.39.70 – RULES GOVERNING INSTALLATION OF HEATING, VENTILATION,
AND AIR CONDITIONING SYSTEMS**

000. LEGAL AUTHORITY.

This chapter is adopted in accordance with Sections 54-5001 and 54-5005(2), Idaho Code. ()

001. TITLE AND SCOPE.

01. Title. These rules are titled IDAPA 24.39.70, "Rules Governing Installation of Heating, Ventilation, and Air Conditioning Systems" (HVAC Rules). ()

02. Scope. These rules establish the minimum standards for heating, ventilation, and air conditioning (HVAC) installation practice, certification, registration, and educational programs. ()

002. (RESERVED)

003. ADMINISTRATIVE APPEALS.

Title 67, Chapter 52, Idaho Code, and IDAPA 04.11.01, "Idaho Rules of Administrative Procedure of the Attorney General," govern administrative appeals and judicial review thereof. ()

004. ADOPTION AND INCORPORATION BY REFERENCE OF THE INTERNATIONAL MECHANICAL CODE, 2018 EDITION; THE INTERNATIONAL FUEL GAS CODE, 2018 EDITION; AND PART V (MECHANICAL) AND PART VI (FUEL GAS) OF THE INTERNATIONAL RESIDENTIAL CODE FOR ONE (1)- AND TWO (2)-FAMILY DWELLINGS, 2018 EDITION.

The 2018 editions of the International Residential Code for One (1)- and Two (2)-Family Dwellings, International Mechanical Code, and International Fuel Gas Code are available at the Division's offices located at 1090 E. Watertower St., Suite, 150 Meridian, Idaho 83642; 1250 Ironwood Dr., Ste. 220, Coeur d'Alene, Idaho 83814; and 2055 Garrett Way, Building 1, Suite 4, Pocatello, Idaho 83201. ()

01. International Mechanical Code. The 2018 Edition, including appendix "A," (herein IMC) is adopted and incorporated by reference with the following amendments: ()

a. Where differences occur between the IMC and Title 54, Chapter 50, Idaho Code and IDAPA 07, Title 07, the provisions in Idaho Code and IDAPA rules apply. ()

b. All references to the International Plumbing Code (IPC) are construed as referring to the Idaho State Plumbing Code (ISPC) as adopted and amended by the Idaho State Plumbing Board. ()

c. All references to the International Code Council Electrical Code (ICC EC) are construed as referring to the National Electrical Code (NEC) as adopted and amended by the Idaho State Electrical Board. ()

d. Section 109. Delete. ()

e. Section 202 Definitions. Delete the definitions provided in the code for the terms identified herein this paragraph and replace with the following: ()

i. Light-Duty Cooking Appliance. Light-duty cooking appliances include gas and electric ovens (including standard, bake, roasting, revolving, retherm, convection, combination convection/steamer, countertop conveyORIZED baking/finishing, deck, pastry, and electric and gas conveyor pizza ovens), electric and gas steam jacketed kettles, electric and gas pasta cookers, electric and gas compartment steamers (both pressure and atmospheric) and electric and gas cheesemelters. ()

ii. Medium-Duty Cooking Appliance. Medium-duty cooking appliances include electric discrete element ranges (with or without oven), electric and gas hot-top ranges, electric and gas griddles, electric and gas double sided griddles, electric and gas fryers (including open deep fat fryers, donut fryers, kettle fryers and pressure fryers), electric and gas tilting skillets (braising pans) and electric and gas rotisseries. ()

f. Section 401.1 Scope. Add the following: Exception: The principles specified in ASHREA 62-2010 may be used as an alternative to this chapter to demonstrate compliance with required ventilation air for occupants. ()

g. Section 504.8.1 Material and size. Add the following exception: Dryer duct may be constructed of ()

installation of any material or to prohibit any design or method of construction not specifically prescribed by this code, provided that any such alternative has been approved. An alternative material, design or method of construction must be approved where the authority having jurisdiction finds that the proposed design is satisfactory and complies with the intent of the provisions of this code, and that the material, method or work offered is, for the purpose intended, at least the equivalent of that prescribed in this code. Compliance with the specific performance-based provisions of this part of the code in lieu of specific requirements of this code will also be permitted as an alternate. ()

e. Add the following as section M1201.3.1 and section G2402.4.1 (201.4.1): Tests. Whenever there is insufficient evidence of compliance with the provisions of this part of the code, or evidence that a material or method does not conform to the requirements of this part of the code, or in order to substantiate claims for alternative materials or methods, the authority having jurisdiction has the authority to require tests as evidence of compliance to be made at no expense to the jurisdiction. Test methods are as specified in this code or by other recognized test standards. In the absence of recognized and accepted test methods, the authority having jurisdiction approves the testing procedures. Tests must be performed by an approved agency. Reports of such tests must be retained by the authority having jurisdiction for the period required for retention of public records. ()

f. Add the following as section M1203.1: Carbon monoxide alarms. For new construction, an approved carbon monoxide alarm must be installed outside of each separate sleeping area in the immediate vicinity of the bedrooms in dwelling units within which fuel-fired appliances are installed and in dwelling units that have attached garages. ()

g. Add the following as section M1203.2: Where required in existing dwellings. Where work requiring a permit occurs in existing dwellings that have attached garages or in existing dwellings within which fuel-fired appliances exist, carbon monoxide alarms must be provided in accordance with Subsection 004.03.f. of these rules. ()

h. Add the following as section M1203.3: Alarm requirements. Single station carbon monoxide alarms must be listed as complying with UL 2034 and must be installed in accordance with this code and the manufacturer's installation instructions. ()

i. Section M1502.4.1 Material and size. Add the following exception: Dryer duct may be constructed of 0.013 (30 gauge) or equivalent if prefabricated 0.016 (28 gauge) ducts and fittings are not available. ()

j. Delete Section M1502.4.2 Duct Installation and replace with the following: Exhaust ducts must be supported at four (4) foot (1,219 mm) intervals and secured in place. The insert end of the duct must extend into the adjoining duct or fitting in the direction of airflow. Ducts must not be joined with screws or similar fasteners that protrude into the inside of the duct. ()

k. Table M1601.1.1 (2) Gauges of Metal Ducts and Plenums Used for Heating or Cooling. Add the following exception: Round duct, enclosed rectangular ducts and fittings less than fourteen (14) inches may be constructed of 0.013 (30 gauge) or equivalent if prefabricated 0.016 (28 gauge) ducts and fittings are not available. ()

l. Section G2417.4 (406.4). Change the last sentence to: Mechanical gauges used to measure test pressure must have a range such that the highest end of the scale is not greater than two (2) times the test pressure nor lower than one and one-half (1.5) times the test pressure. ()

m. Section G2417.4.1 (406.4.1). Test Pressure. Not less than twenty (20) psig (one hundred forty (140) kPa gauge) test pressure is required for systems with a maximum working pressure up to ten (10) inches water column. For systems with a maximum working pressure between ten (10) inches water column and ten (10) psig (seventy (70) kPa gauge), not less than sixty (60) psig (four hundred twenty (420) kPa gauge) test pressure is required. For systems over ten (10) psig (seventy (70) kPa gauge) working pressure, minimum test pressure may be no less than six (6) times working pressure. ()

n. Section G2417.4.2 (406.4.2). The test duration may not be less than twenty (20) minutes. ()

013. CERTIFICATES OF COMPETENCY -- ISSUANCE, RENEWAL, EXPIRATION -- REVIVAL.

01. Issuance. Certificates of competency will be issued in such a manner as to create a renewal date that coincides with the birth month of the individual to whom the certificate is issued and allows for renewals every three (3) years. Certificates of competency are issued for a period of no less than one (1) year and no more than (3) three years. The fee for issuance of certificates of competency will be prorated based on the number of months for which the certificate is issued. ()

02. Renewal. Certificates of competency will be renewed using the birth month of the individual to whom the certificate is issued as the expiration date. Certificates of competency are renewed for a period of no less than one (1) year and no more than three (3) years. The fee for renewal of certificates of competency will be prorated based on the number of months for which the certificate is issued. ()

03. Expiration-Revival. ()

a. Certificates that are not timely renewed will expire on the last day of the month in which the renewal is due. ()

b. Revived certificates will be issued in such a manner as to create a renewal date that coincides with the birth month of the applicant so as to create a staggered system of renewal. ()

014. -- 019. (RESERVED)

020. HVAC CONTRACTOR AND HVAC JOURNEYMAN APPLICATIONS FOR EXAMINATION AND CERTIFICATES OF COMPETENCY, AND REGISTRATION OF APPRENTICES.

01. Application Forms. All applications for certificates and all applications for registration must be submitted on forms provided by the administrator and be properly completed, giving all pertinent information with notarized signatures. ()

02. Application, Renewal, and Registration Fees. Fees for applications for examination, certificates of competency, renewal of certificates, and fees for apprentice registration are as set forth in Section 54-5012, Idaho Code. ()

03. Application Submission. All applications must be submitted to the board and be approved by an administrator before any examination may be taken and before any certificate of competency is issued. ()

021. HVAC CONTRACTOR CERTIFICATE OF COMPETENCY - REQUIREMENTS.

01. Bond. Applicants must provide a compliance bond in the amount of two thousand dollars (\$2,000). Any such bond is required to be effective for the duration of the contractor licensing period. ()

02. Qualification. Applicants must provide proof, satisfactory to the Board, of having legally acted as an HVAC journeyman for a period of not less than twenty-four (24) months. ()

03. Examination. Applicants for certification as HVAC contractors must successfully complete the examination designated by the Board. ()

04. Out-of-State Contractor Applications. ()

a. An out-of-state applicant for a contractor certificate of competency shall first obtain an Idaho journeyman certificate of competency in accordance with Section 023 of these rules. The applicant shall pay all applicable application and examination fees to the Division and successfully complete the contractor examination administered by the Division. The applicant shall file the compliance bond required by Section 54-5007, Idaho Code, with the Division upon successful completion of the examination. Applications that are incomplete in any detail will be returned as unacceptable or denied. ()

ii. Proof of eight (8) years, defined as a minimum of sixteen thousand (16,000) hours, of HVAC work experience of a nature at least equivalent to that which an HVAC apprentice must perform in Idaho. ()

024. HVAC HEARTH SPECIALTY JOURNEYMAN CERTIFICATES OF COMPETENCY LIMITATIONS: REQUIREMENTS.

Certification as a hearth specialty journeyman entitles the holder to install hearth appliances and the associated gas lines. Hearth Specialty Journeymen are required to meet the experience requirement and either the education or examination requirement to receive a certificate of competency. ()

01. Experience. Demonstrate, to the satisfaction of the board, a minimum of one (1) year experience working in the trade, in compliance with the requirements of the state in which the applicant received his supervision, or as a registered HVAC apprentice or registered HVAC specialty apprentice making HVAC installations on the job under the supervision of a qualified HVAC journeyman or qualified HVAC specialty journeyman. ()

02. Education. Successfully complete a board approved training course(s), such as the National Fireplace Institute program and a minimum of sixty (60) hours of education in fuel gas code and piping installation methods. ()

03. Examination. Successfully complete an examination designated by the board. ()

025. HVAC APPRENTICE REQUIREMENTS FOR REGISTRATION.

01. Registration. To become an apprentice, a person shall comply with Section 54-5012, Idaho Code, and be a minimum of eighteen (18) years of age or sixteen (16) years of age if registered by the Bureau of Apprenticeship and Training of the United States Department of Labor. To renew a registration, an apprentice shall show proof of enrollment in a Board-approved training course or completion of eight (8) hours of Board-approved continuing education for each year of the prior registration period. ()

02. Supervision. Each apprentice must work under the supervision of a certified journeyman. ()

026. HVAC SPECIALTY APPRENTICE REQUIREMENTS FOR REGISTRATION.

Requirements for HVAC Specialty Apprentice. ()

01. Age. Minimum of eighteen (18) years of age unless registered in a Bureau of Apprenticeship Training (BAT) certified HVAC training program. ()

02. Training. Maintain enrollment in or successfully complete a training program approved by the board. ()

03. Supervision. Work under the supervision of a certificated HVAC journeyman or certificated HVAC specialty journeyman. ()

027. HVAC WASTE OIL HEATING SPECIALTY JOURNEYMAN CERTIFICATES OF COMPETENCY LIMITATIONS: REQUIREMENTS.

Certification as a waste oil heating specialty journeyman entitles the holder to install non-duct connected waste oil heaters. Waste oil heating specialty journeymen are limited to the maintenance, installation, and repair of the equipment, controls, and piping directly associated with the waste oil heater, tank, and burner only. Any plumbing, electrical, ducting, venting, or associated equipment beyond the waste oil heater, tank, and burner must be installed by others. Applicants for the waste oil heating specialty journeyman certificate of competency must: ()

01. Experience. Demonstrate to the satisfaction of the board, a minimum of one (1) year experience making waste oil heating installations under the supervision of a qualified HVAC journeyman or HVAC Waste Oil Heating specialty journeyman. ()

02. Examination. Successfully complete a waste oil burner manufacturers certification or examination as approved by the board. ()

following permit fees apply to all residential installations:

Type	Fee
Base permit	\$100
Furnace, furnace-air conditioner combination, heat pump, air conditioner, evaporative cooler, unit heater, space heater, decorative gas-fired appliance, incinerator, boiler, pool heater, mini-split system, free-standing solid-fuel stove, factory-built gas fireplace, or similar fixture or appliance, including ducts, vents, and flues attached thereto	Plus \$30 per first fixture or appliance Plus \$15 per additional fixture or appliance
Exhaust duct or ventilation duct, including dryer vents, range hood vents, cook stove vents, bath fan vents, and similar exhaust ducts or ventilation ducts	Plus \$15 per first duct Plus \$5 per additional duct
Fuel gas piping system	Plus \$5 per appliance outlet
Hydronic systems	Plus \$5 per zone

()

02. Miscellaneous. The following permit fees apply for the types of permits listed:

Type	Fee
Requested inspection	\$65 per hour or portion thereof plus costs of out-of-state travel
Mobile or manufactured home	\$65 per inspection
Modular building	
Plan check or technical service	\$65 per hour or portion thereof

()

03. Other Installations Including Industrial and Commercial. The permit fees listed in this Subsection apply to installations not specifically mentioned elsewhere in this schedule. The HVAC system cost is the cost to the owner of labor charges and other costs incurred to complete the installation of equipment and materials installed as part of the HVAC system. All permit fees calculated under this Subsection are based on the total HVAC system cost, which must be listed on the permit.

HVAC System Cost	Fee
Up to \$10,000	\$60 plus 2% of HVAC system cost
\$10,000 to \$100,000	\$260 plus 1% of HVAC system cost exceeding \$10,000
Over \$100,000	\$1,160 plus 5% of HVAC system cost exceeding \$100,000

()

04. Additional Fees. A fee of sixty-five dollars (\$65) per hour or portion thereof applies to trips to inspect: ()

a. When the permit holder has given notice to the Division that the work is ready for inspection and it is not; ()

b. If the permit holder has not accurately identified the work location; ()

c. If the inspector cannot gain access to make the inspection; ()

within one (1) year of an earlier violation. ()

02. Knowingly Employing. Knowingly employing a person who does not hold a valid Idaho HVAC certification or apprentice registration, as required by Section 54-5008, Idaho Code, to perform HVAC installations. ()

03. Certification or Registration. Except as provided by Section 54-5001, Idaho Code, performing HVAC work as an HVAC journeyman as defined by Section 54-5003(4), Idaho Code; specialty journeyman as defined by Section 54-5003(7), Idaho Code; apprentice as defined by Section 54-5003(2), Idaho Code; or specialty apprentice as defined by Section 54-5003(5), Idaho Code, without a valid certification or registration. ()

04. Supervision. Working as an HVAC apprentice or specialty apprentice without the required journeyman supervision or employing an apprentice without providing the required journeyman supervision. ()

05. Performance Outside Scope of Specialty License. Performance of any HVAC installation, alteration, or maintenance by an HVAC specialty contractor or specialty journeyman outside the scope of the specialty certification. ()

06. Fees and Permits. Failing to pay applicable fees or properly post an HVAC permit for, or to request an inspection of, any installation, alteration, improvement, or extension of any piping, venting, ductwork, appliances and appurtenances in connection with any HVAC system or subsystems of such. ()

07. Corrections. Failure to make corrections in the time allotted in the notice on any HVAC installation as set forth in Section 54-5019, Idaho Code. ()

08. Gross Violation. In the case of continued, repeated, or gross violation of Title 54, Chapter 50, Idaho Code, or these rules, a certification revocation will be initiated for certificated individuals under this chapter and non-certificated individuals is subject to prosecution by the appropriate jurisdiction under Idaho law. ()

071. -- 999. (RESERVED)